


- SECURITY SYSTEM NOTES**
- CONDUIT STUB-DOWN INTO DOOR FRAME (SWINGING DOOR), LEAVE 3 FT. OF ALL CABLES HANGING FROM CONDUIT.
 - CONDUIT STUB-DOWN INTO DOOR FRAME (SLIDING DOOR), LEAVE 3 FT. OF ALL CABLES HANGING FROM CONDUIT.
 - 1" CONDUIT WITH 1-BELDON #8205, 1-BELDON #8762 AND 1-BELDON #8691-12 (18 GA.) BACK TO DEC CONTROL UNIT. LEAVE 8 FT. OF ALL CABLES HANGING FROM CONDUIT AT DEC CONTROL UNIT.
 - CONDUIT STUB-DOWN INTO DOOR FRAME (POSITION INDICATOR), LEAVE 3 FT. OF CABLE HANGING FROM CONDUIT.
 - 1/2" CONDUIT WITH 1-BELDON #8205-2 (20 GA.) BACK TO DEC CONTROL UNIT. LEAVE 8 FT. OF CABLE HANGING FROM CONDUIT AT DEC CONTROL UNIT.
 - CONDUIT STUB-DOWN INTO DOOR FRAME FOR POWER TO ELEC. DOOR OPERATOR. CONDUIT SHALL BE CONTINUOUS FROM DOOR FRAME TO DOOR FRAME-NO J-BOXES. LEAVE 3 FT. OF WIRE HANGING FROM EACH STUB-DOWN.
 - J-BOX @ 54" AFF. (FOR CALL BUTTON) WITH 1/2" C. UP TO SPEAKER LOCATION. INSTALL 1-BELDON #8205-2 (20 GA.) CABLE IN CONDUIT. CABLE SHALL BE ROUTED THRU SPEAKER HOUSING AND BACK TO DEC CONTROL UNIT CONTINUOUS WITHOUT SPLICE. LEAVE 3 FT. OF CABLE HANGING AT J-BOX.
 - J-BOX FLUSH IN CIG. (FOR SOUND SYSTEM SPEAKER). VERIFY REQUIREMENTS W/SECURITY SYSTEM CONTRACTOR. LEAVE 3 FT. OF ALL CABLES HANGING FROM J-BOX.
 - CONDUIT STUB-DOWN THRU CEILING (FOR SOUND SYSTEM SPEAKER). VERIFY REQUIREMENTS W/SECURITY SYSTEM CONTRACTOR. LEAVE 3 FT. OF ALL CABLES HANGING FROM CONDUIT.
 - 1/2" C. WITH 1-BELDON #8762-2 (20 GA.) FOR SOUND SYSTEM & 1-BELDON #8205-2 (20 GA.) FOR CALL BUTTON (SEE NOTE 7) BACK TO DEC CONTROL UNIT. ALL SOUND SYSTEM CABLE SHALL BE CONTINUOUS WITHOUT SPLICE. LEAVE 8 FT. OF ALL CABLES HANGING FROM CONDUIT AT DEC CONTROL UNIT.
 - CONDUIT STUB-DOWN INTO DOOR FRAME (FOR ELEC. STRIKE CONTROL), LEAVE 3 FT. OF CABLE HANGING FROM CONDUIT.
 - 3/4" C. WITH 3 #16GND CONDUCTORS (FOR ELEC. STRIKE CONTROL) BACK TO DEC CONTROL UNIT. LEAVE 8 FT. OF CABLE HANGING FROM CONDUIT AT DEC CONTROL UNIT.
 - J-BOX FOR CONN. TO OVERHEAD DOOR CONTROLLER (MOTOR STARTER). VERIFY LOCATION. LEAVE 3 FT. OF CABLE HANGING FROM J-BOX.
 - 3/4" C. WITH BELDEN #9774-12 COND. (18 GA) BACK TO DEC CONTROL UNIT. LEAVE 8 FT. OF CABLE HANGING FROM CONDUIT AT DEC CONTROL UNIT.
 - CONDUIT STUB-DOWN THRU CEILING (FOR CCTV CAMERA). VERIFY EXACT LOCATION W/SECURITY SYSTEM CONTRACTOR. LEAVE 3 FT. OF ALL CABLES HANGING FROM CONDUIT.
 - 3/4" C. WITH 1-BELDEN #8959/J AND 1-BELDEN #8205-2 (20 GA.) BACK TO DEC CONTROL UNIT. LEAVE 8 FT. OF ALL CABLES HANGING FROM CONDUIT AT DEC CONTROL UNIT.
 - 1/2" C. W/P/A SYSTEM WIRING BACK TO J-BOX 'A' EACH HOMERUN INDICATES A ZONE OF CONTROL. J-BOX 'A' SHALL BE 12"x12" x 3" W/BLANK COVER MOUNTED AT 18" A.F.F.

GROUND FLOOR- COMMUNICATIONS SYSTEM
SCALE 1/8" = 1'-0"



SHEPHERD + BOYD
ARCHITECTS/PLANNERS & INTERIORS
DOUGLAS BUILDING
DALLAS, TEXAS 75206
TELEPHONE 214/691-9000

A NEW POLICE FACILITY FOR THE
TOWN OF ADDISON
4799 AIRPORT PARKWAY
ADDISON, TEXAS 75248



REVISIONS

NO.	DATE	DESCRIPTION

DATE
7-12-82

SHEET
E-6