| Kimley-Horn and A   |  |          |          |                          | Priority: 6                             |  |  |  |
|---|--|----------|----------|--------------------------|---|--|--|--|
| Project Description   | n for Unsignalized Intersection              |          |          |                          |   |  |  |  |
| Client:   | Town of Addison                              |          |          |                          | Date: 1/2/18                            |  |  |  |
| Program:  | ADA Self-Evaluation and Transition Plan      |          |          | P                        | repared By: CMP                         |  |  |  |
| KHA No.:  | 063543021                                    |          |          | C                        | hecked By: EPE                          |  |  |  |
| Corridor :  | Paladium Dr                                  |          |          |                          | GPS ID: 222                             |  |  |  |
| Project Name:   | Intersection of Paladium Dr and Lochinvar Dr |          |          |                          |   |  |  |  |
| Town:   | Addison                                      |          |          |                          |   |  |  |  |
| liam Na   | Item Dependention                            | Quantitu | Unit     | Lisit Dries              | ltom Cost                               |  |  |  |
| Item No.  | Item Description                             | Quantity | <u>.</u> | Unit Price               | Item Cost                               |  |  |  |
|   | EXCAVATION (ROADWAY)                         | 0        | CY       | \$ 10.00                 | •··                                     |  |  |  |
|   | CONC CURB (TY II)                            | 0        | LF       | \$ 15.00                 |   |  |  |  |
|   | CONC SIDEWALKS (4")                          | 0        | SY       | \$ 45.00                 |   |  |  |  |
|   | CURB RAMPS                                   | 6        | EA       | \$ 1,500.00              |   |  |  |  |
|   | RETROFIT DET WARN SURF (CAST IN PLACE)       | 0        | SF       | \$ 50.00                 |   |  |  |  |
|   | REMOVING CONC (SIDEWALKS)                    |          | SY       | \$ 9.00                  |   |  |  |  |
| TxDOT 677   | ELIM EXT PAVE MRK & MRKS                     | 0        | LF       | \$ 2.80                  |   |  |  |  |
|   | REFL PAV MRK PREP, TY I & TY II (W) 24"(SLD) | 144      | LF       | \$ 8.50                  | ÷                                       |  |  |  |
|   | REPAVE ROADWAY                               | 1        | LS       | \$ 5,000.00              |   |  |  |  |
|   | FIX PONDING                                  | 0        | LS       | \$ 2,000.00              |   |  |  |  |
|   | FIX CURB RAMP TRANSITION                     | 0        | LS       | \$ 2,000.00              |   |  |  |  |
|   | MEDIAN NOSE MODIFICATION                     | 0        | LS<br>LS | \$ 5,000.00              |   |  |  |  |
|   | REMOVE TEMPORARY OBSTRUCTION                 | <u> </u> |          | \$ 500.00<br>\$ 2,000.00 |   |  |  |  |
| IFIX CURB RAMP COUNTER SLOPE 0 LS \$ 2,000.00 Basis for Cost Projection Subtota |  |          |          |                          |   |  |  |  |
| Dasis IUI COSI PIOJE  | <ul> <li>No Design Completed</li> </ul>      |          | Engi     | neering: (% +/-) 20%     | • • • • • • •                           |  |  |  |
|   | <ul> <li>Preliminary Design</li> </ul>       |          |          | tingency: (% +/-) 20%    |   |  |  |  |
|   | <ul> <li>Final Design</li> </ul>             |          | Con      | Estimated Project Cost:  | • |  |  |  |
|   |  |          |          | Estimateu Project Cost:  | ə 22,000.00                             |  |  |  |

## Project Location



## Field Observations

| Intersection Issues  |     | Cros | swalk |     | Possible Solutions                                     |
|--|-----|------|-------|-----|--|
|  |     | E    | S     | W   | Possible Solutions                                     |
| Path of travel pavement condition  | N/A | Good | Good  | N/A |  |
| Path of travel running slope is greater than 5%                              | N/A |      |       | N/A |  |
| Path of travel cross slope is greater than 2% for stop control<br>approaches | N/A | N/A  | х     | N/A | Repave roadway and install crosswalk pavement markings |
| Path of travel cross slope is greater than 5% for free-flow approaches       | N/A |      | N/A   | N/A |  |
| Crosswalk width is less than 6'  | N/A | N/A  | N/A   | N/A | Install crosswalk pavement markings                    |
| Crosswalk striping condition   |     | None | None  | N/A | instan Gosswaik pavement indi Kiliys                   |

| Curb Ramp ID ('z' or 'i' in ramp label indicates no                   |            |                |          |          |   |  |
|---|------------|----------------|----------|----------|---|--|
| Curb Ramp Issues  |            | existing ramp) |          |          | mp) Possible Solutions                                  |  |
|   | 1 <i>z</i> | 2z             | 3z       | 4z       |   |  |
| Curb ramp does not exist and is needed                                | Х          | Х              | Х        | Х        | Install curb ramp; if median improvement, see shapefile |  |
| Curb ramp does not land in crosswalk                                  | İ          |                | j        | <u> </u> |   |  |
| No 4' x 4' clear space at base of curb ramp                           |            |                | ļ        |          |   |  |
| Curbed side is not 90° or has traversable adjacent surface            |            |                |          |          |   |  |
| Flare cross slope is greater than 10%                                 |            |                | 1        |          |   |  |
| Curb ramp running slope is greater than 8.3%                          |            |                |          |          |   |  |
| Blended transition running slope is greater than 5%                   |            |                |          |          |   |  |
| Cut-thru ramp running slope is greater than 5%                        |            |                | 1        |          |   |  |
| Curb ramp cross slope is greater than 2%                              |            |                |          |          |   |  |
| Cut-thru ramp cross slope is greater than 2%                          |            |                |          |          |   |  |
| Curb ramp width is less than 48"                                      |            |                | 1        |          |   |  |
| Cut-thru ramp width is less than 60"                                  |            |                |          | T        |   |  |
| Permanent obstruction (>0.25") in curb ramp/landing/flares            |            |                |          |          |   |  |
| Temporary obstruction (>0.25") in curb ramp/landing/flares            | <u>.</u>   | İ              | j        | <u> </u> |   |  |
| No textured surface at base of curb ramp                              | l          |                | <u> </u> | <u> </u> |   |  |
| No color contrast at base of curb ramp                                |            |                | j        |          |   |  |
| Landing area does not exist and is needed                             |            |                | <u>.</u> |          |   |  |
| Landing area is less than 5' x 5' or slopes greater than 2%           | L          |                | l        |          |   |  |
| Curb ramp transition onto roadway is greater than 0.25"               | <b> </b>   |                | ļ        | <u> </u> |   |  |
| Counter slope of the gutter or street at the foot of the curb ramp is |            |                |          |          |   |  |
| greater than 5%   |            |                |          |          |   |  |
| Ponding occurs at base of curb ramp                                   | I          |                | 1        |          |   |  |


Comment: Existing sidewalk, curb ramp, and/or striping configurations permit pedestrians to cross the major street. An Engineering study is needed to confirm crossing should be accomm



Corner 1 No Ramp (1z)



Corner 3 No Ramp (3z)



Corner 2 No Ramp (2z)



Corner 4 No Ramp (4z)

## Opinion of Probable Construction Cost Disclaimer:

The Engineer has no control over the cost of labor, materials, equipment, or over the Contractor's methods of determining prices or over competitive bidding or market conditions. Opinions of probable costs provided herein are based on the information known to Engineer at this time and represent only the Engineer's judgment as a design professional familiar with the construction industry. The Engineer cannot and does not guarantee that proposals, bids, or actual construction costs will not vary from its opinions of probable costs.

## Project Location Map Sources:

Esri, DeLorme, NAVTEQ, USGS, Intermap, iPC, NRCAN, Esri Japan, METI, Esri China (Hong Kong), Esri (Thailand), TomTom, 2013, DigitalGlobe, GeoEye, i-cubed, USDA, AEX, Getmapping, Aerogrip, IGN, IGP, swisstopo, and the GIS User Community