	Associates, Inc. on for Unsignalized Intersection				Priority: 5
ient: ogram: HA No.:	Town of Addison ADA Self-Evaluation and Transition Plan 063543021		Date: 1/2/18 Prepared By: CMP Checked By: EPE		
orridor :	Beltway Dr				GPS ID: 242
oject Name:	Intersection of Beltway Dr and driveway (Lat. 32.9519; Lo	ong96.8396)			
own:	Addison				
Item No.	Item Description	Quantity	Unit	Unit Price	Item Cost
	EXCAVATION (ROADWAY)	0	CY	\$ 10.00 \$	-
xDOT 529-6002	CONC CURB (TY II)	0	LF	\$ 15.00 \$	-
xDOT 531-6001	CONC SIDEWALKS (4")	0	SY	\$ 45.00 \$	-
TxDOT 531	CURB RAMPS	2	EA	\$ 1,500.00 \$	3,000.0
	RETROFIT DET WARN SURF (CAST IN PLACE)	0	SF	\$ 50.00 \$	-
	REMOVING CONC (SIDEWALKS)	23	SY	\$ 9.00 \$	207.0
TxDOT 677	ELIM EXT PAVE MRK & MRKS	0	LF	\$ 2.80 \$	-
TxDOT 666/678	REFL PAV MRK PREP, TY I & TY II (W) 24"(SLD) REPAVE ROADWAY	0	LF	\$ 8.50 \$ \$ 5.000.00 \$	-
	FIX PONDING	0	LS LS	\$ 5,000.00 \$ \$ 2,000.00 \$	-
	FIX CURB RAMP TRANSITION	2	LS	\$ 2,000.00 \$	4,000.0
	MEDIAN NOSE MODIFICATION		LS	\$ 5,000.00 \$	
	REMOVE TEMPORARY OBSTRUCTION	0	LS	\$ 500.00 \$	-
	FIX CURB RAMP COUNTER SLOPE	0	LS	\$ 2,000.00 \$	-
asis for Cost Proj				Subtotal: \$	7,207.0
	 No Design Completed Preliminary Design 			eering: (% +/-) 20% \$ ngency: (% +/-) 20% \$	1,896.5
	 Final Design 		Contin	Estimated Project Cost: \$	1,896.5 11,000.0
1-0-	Beltway D	Linbergh Di rapaho Rd Langland R		1A 242	
eld Observation	s Intersection Issues N	Crosswalk E S	W	Possible Solutions	
	ment condition	2 0			

Curb Ramp ID ('z' or 'i' in ramp label indicates no							
Curb Ramp Issues		existing ramp)		Possible Solutions			
	1A	2A					
Curb ramp does not exist and is needed		l					
Curb ramp does not land in crosswalk	<u> </u>		j				
No 4' x 4' clear space at base of curb ramp	<u> </u>						
Curbed side is not 90° or has traversable adjacent surface	1]				
Flare cross slope is greater than 10%		Х					
Curb ramp running slope is greater than 8.3%		Х					
Blended transition running slope is greater than 5%							
Cut-thru ramp running slope is greater than 5%		1	1	Remove and replace curb ramp			
Curb ramp cross slope is greater than 2%		Х		internove and replace curb famp			
Cut-thru ramp cross slope is greater than 2%			1				
Curb ramp width is less than 48"	I]				
Cut-thru ramp width is less than 60"	1						
Permanent obstruction (>0.25") in curb ramp/landing/flares]				
Temporary obstruction (>0.25") in curb ramp/landing/flares	İ	<u>.</u>	j				
No textured surface at base of curb ramp	X	Х		For intersection, commercial driveway, and park ramps, install			
No color contrast at base of curb ramp	Х	Х	j	color truncated domes			
Landing area does not exist and is needed	<u> </u>	<u> </u>					
Landing area is less than 5' x 5' or slopes greater than 2%	X	Х		Remove and replace landing area			
Curb ramp transition onto roadway is greater than 0.25"		Х		Fix curb ramp transition			
Counter slope of the gutter or street at the foot of the curb ramp is		1					
greater than 5%							
Ponding occurs at base of curb ramp	1	1					



Ramp 1A



Ramp 2A

Opinion of Probable Construction Cost Disclaimer:

The Engineer has no control over the cost of labor, materials, equipment, or over the Contractor's methods of determining prices or over competitive bidding or market conditions. Opinions of probable costs provided herein are based on the information known to Engineer at this time and represent only the Engineer's judgment as a design professional familiar with the construction industry. The Engineer cannot and does not guarantee that proposals, bids, or actual construction costs will not vary from its opinions of probable costs.

Project Location Map Sources:

Esri, DeLorme, NAVTEQ, USGS, Intermap, iPC, NRCAN, Esri Japan, METI, Esri China (Hong Kong), Esri (Thailand), TomTom, 2013, DigitalGlobe, GeoEye, i-cubed, USDA, AEX, Getmapping, Aerogrip, IGN, IGP, swisstopo, and the GIS User Community