Kimley-Horn and Associates, Inc.							
Project Description	n for Unsignalized Intersection						
Client:	Town of Addison					Date: 1/2/18	
Program:	ADA Self-Evaluation and Transition Plan				Prepare	d By: CMP	
KHA No.:	063543021				Checke	d By: EPE	
Corridor :	Proton Rd				GF	PS ID: 251	
Project Name:	Intersection of Proton Dr and Heritage Ln						
Town:	Addison						
Item No.	Item Description	Quantity	Unit	Unit Price		Item Cost	
	EXCAVATION (ROADWAY)		CY	\$ 10.00		Item Cost	
	CONC CURB (TY II)	0	LF	\$ 10.00			
	CONC SIDEWALKS (4")		SY	\$ 45.00		270.00	
	CURB RAMPS	6	EA	\$ 1,500.00		9,000.00	
	RETROFIT DET WARN SURF (CAST IN PLACE)	0	SF	\$ 50.00			
	REMOVING CONC (SIDEWALKS)	21	SY	\$ 9.00		189.00	
	ELIM EXT PAVE MRK & MRKS	0	LF	\$ 2.80		-	
TxDOT 666/678	REFL PAV MRK PREP, TY I & TY II (W) 24"(SLD)	254	LF) \$	2,159.00	
	REPAVE ROADWAY	1	LS	\$ 5,000.00) \$	5,000.00	
	FIX PONDING	0	LS	\$ 2,000.00) \$	-	
	FIX CURB RAMP TRANSITION	1	LS	\$ 2,000.00) \$	2,000.00	
	MEDIAN NOSE MODIFICATION	0	LS	\$ 5,000.00		-	
	REMOVE TEMPORARY OBSTRUCTION	0	LS	\$ 500.00		-	
	FIX CURB RAMP COUNTER SLOPE	0	LS	\$ 2,000.00		-	
Basis for Cost Proje			Subtota		18,618.00		
	☑ No Design Completed				6 \$	4,191.00	
	Preliminary Design	Con		6 \$	4,191.00		
	Final Design			Estimated Project Cos	t:\$	27,000.00	

Project Location



Field Observations

Intersection Issues		Cros	swalk		Possible Solutions	
		E	S	W	Possible Solutions	
Path of travel pavement condition	N/A	Good	Good	Good		
Path of travel running slope is greater than 5%	N/A					
Path of travel cross slope is greater than 2% for stop control approaches	N/A	N/A	х	N/A	Repave roadway and install crosswalk pavement markings	
Path of travel cross slope is greater than 5% for free-flow approaches	N/A		N/A			
Crosswalk width is less than 6'	N/A	N/A	N/A	N/A	Install crosswalk pavement markings	
Crosswalk striping condition	N/A	None	None	None	install crosswaik pavement markings	

Curb Ramp ID ('z' or 'i' in ramp label indicates no							
Curb Ramp Issues				existing ra	mp) Possible Solutions		
	1 <i>z</i>	2z	3A	4A			
Curb ramp does not exist and is needed	Х	Х]		Install curb ramp; if median improvement, see shapefile		
Curb ramp does not land in crosswalk	İ		<u> </u>	<u> </u>]			
No 4' x 4' clear space at base of curb ramp							
Curbed side is not 90° or has traversable adjacent surface							
Flare cross slope is greater than 10%							
Curb ramp running slope is greater than 8.3%							
Blended transition running slope is greater than 5%							
Cut-thru ramp running slope is greater than 5%					Remove and replace curb ramp		
Curb ramp cross slope is greater than 2%				Х	Remove and replace curb ramp		
Cut-thru ramp cross slope is greater than 2%			<u> </u>				
Curb ramp width is less than 48"			Х				
Cut-thru ramp width is less than 60"							
Permanent obstruction (>0.25") in curb ramp/landing/flares							
Temporary obstruction (>0.25") in curb ramp/landing/flares	_		<u> </u>	<u> </u>			
No textured surface at base of curb ramp	ļ		Х	Х	For intersection, commercial driveway, and park ramps, install		
No color contrast at base of curb ramp	_		Х	X	color truncated domes		
Landing area does not exist and is needed	ļ		X	X	Install landing area		
Landing area is less than 5' x 5' or slopes greater than 2%	 		ļ	<u> </u>			
Curb ramp transition onto roadway is greater than 0.25"	ļ		X	ļļ	Fix curb ramp transition		
Counter slope of the gutter or street at the foot of the curb ramp is							
greater than 5%							
Ponding occurs at base of curb ramp			1				

Comment: Existing sidewalk, curb ramp, and/or striping configurations permit pedestrians to cross the major street. An Engineering study is needed to confirm crossing should be accomm



Corner 1 No Ramp (1z)



Ramp 3A



Corner 2 No Ramp (2z)



Ramp 4A

Opinion of Probable Construction Cost Disclaimer:

The Engineer has no control over the cost of labor, materials, equipment, or over the Contractor's methods of determining prices or over competitive bidding or market conditions. Opinions of probable costs provided herein are based on the information known to Engineer at this time and represent only the Engineer's judgment as a design professional familiar with the construction industry. The Engineer cannot and does not guarantee that proposals, bids, or actual construction costs will not vary from its opinions of probable costs.

Project Location Map Sources:

Esri, DeLorme, NAVTEQ, USGS, Intermap, iPC, NRCAN, Esri Japan, METI, Esri China (Hong Kong), Esri (Thailand), TomTom, 2013, DigitalGlobe, GeoEye, i-cubed, USDA, AEX, Getmapping, Aerogrip, IGN, IGP, swisstopo, and the GIS User Community