Kimley-Horn and A					Priority: 5
Project Description	n for Unsignalized Intersection				
Client:	Town of Addison				Date: 1/2/18
Program:	ADA Self-Evaluation and Transition Plan			P	repared By: CMP
KHA No.:	063543021			(Checked By: EPE
Corridor :	Brookwood Ln				GPS ID: 287
Project Name:	Intersection of Brookwood Ln and Parker Ct				
Town:	Addison				
Item No.	Item Description	Quantity	Unit	Unit Price	Item Cost
	EXCAVATION (ROADWAY)	0	CY	\$ 10.00	
	CONC CURB (TY II)	0	LF	\$ 15.00	
	CONC SIDEWALKS (4")	0	SY	\$ 45.00	\$-
TxDOT 531	CURB RAMPS	4	EA	\$ 1,500.00	\$ 6,000.00
TxDOT 5003-6002	RETROFIT DET WARN SURF (CAST IN PLACE)	10	SF	\$ 50.00	\$ 500.00
TxDOT 104-6015	REMOVING CONC (SIDEWALKS)	8	SY	\$ 9.00	\$ 72.00
	ELIM EXT PAVE MRK & MRKS	0	LF	\$ 2.80	\$-
TxDOT 666/678	REFL PAV MRK PREP, TY I & TY II (W) 24"(SLD)	206	LF	\$ 8.50	\$ 1,751.00
	REPAVE ROADWAY	0	LS	\$ 5,000.00	\$-
	FIX PONDING	0	LS	\$ 2,000.00	\$-
	FIX CURB RAMP TRANSITION	2	LS	\$ 2,000.00	\$ 4,000.00
	MEDIAN NOSE MODIFICATION	0	LS LS	\$ 5,000.00	
	REMOVE TEMPORARY OBSTRUCTION	0	LS	\$ 500.00	\$ -
	FIX CURB RAMP COUNTER SLOPE	0	LS	\$ 2,000.00	
Basis for Cost Proje				Subtotal:	• /
	No Design Completed			ngineering: (% +/-) 20%	
	Preliminary Design		Co	ontingency: (% +/-) 20%	• ,
	Final Design			Estimated Project Cost:	\$ 18,000.00

Project Location



Field Observations

Intersection Issues		Cros	swalk		Possible Solutions
		E	S	W	Possible Solutions
Path of travel pavement condition	N/A	Good	Good	Good	
Path of travel running slope is greater than 5%	N/A				
Path of travel cross slope is greater than 2% for stop control approaches	N/A	N/A		N/A	
Path of travel cross slope is greater than 5% for free-flow approaches	N/A		N/A		
Crosswalk width is less than 6'	N/A	N/A	N/A	N/A	Install crosswalk pavement markings
Crosswalk striping condition	N/A	None	None	None	insian crosswark pavement markings

Curb Ramp ID ('z' or 'i' in ramp label indicates no							
Curb Ramp Issues				existing	ramp) Possible Solutions		
	1 <i>z</i>	2z	3A	4A			
Curb ramp does not exist and is needed	Х	Х]		Install curb ramp; if median improvement, see shapefile		
Curb ramp does not land in crosswalk	l		j	<u> </u>]			
No 4' x 4' clear space at base of curb ramp	i		İ	ii			
Curbed side is not 90° or has traversable adjacent surface							
Flare cross slope is greater than 10%				Х			
Curb ramp running slope is greater than 8.3%				Х			
Blended transition running slope is greater than 5%							
Cut-thru ramp running slope is greater than 5%					Remove and replace curb ramp		
Curb ramp cross slope is greater than 2%				Х	Remove and replace curb ramp		
Cut-thru ramp cross slope is greater than 2%							
Curb ramp width is less than 48"				Х			
Cut-thru ramp width is less than 60"							
Permanent obstruction (>0.25") in curb ramp/landing/flares	<u> </u>						
Temporary obstruction (>0.25") in curb ramp/landing/flares	ļ		<u> </u>	<u></u>			
No textured surface at base of curb ramp	<u>.</u>		Х	Х	For intersection, commercial driveway, and park ramps, install		
No color contrast at base of curb ramp	İ		Х	Х	color truncated domes		
Landing area does not exist and is needed	ļ		Х	Х	Install landing area		
Landing area is less than 5' x 5' or slopes greater than 2%			<u> </u>	L			
Curb ramp transition onto roadway is greater than 0.25"	ļ		Х	Х	Fix curb ramp transition		
Counter slope of the gutter or street at the foot of the curb ramp is							
greater than 5%	1		1	1			
Ponding occurs at base of curb ramp							

Comment: Existing sidewalk, curb ramp, and/or striping configurations permit pedestrians to cross the major street. An Engineering study is needed to confirm crossing should be accomm



Corner 1 No Ramp (1z)



Ramp 3A



Corner 2 No Ramp (2z)



Ramp 4A

Opinion of Probable Construction Cost Disclaimer:

The Engineer has no control over the cost of labor, materials, equipment, or over the Contractor's methods of determining prices or over competitive bidding or market conditions. Opinions of probable costs provided herein are based on the information known to Engineer at this time and represent only the Engineer's judgment as a design professional familiar with the construction industry. The Engineer cannot and does not guarantee that proposals, bids, or actual construction costs will not vary from its opinions of probable costs.

Project Location Map Sources:

Esri, DeLorme, NAVTEQ, USGS, Intermap, iPC, NRCAN, Esri Japan, METI, Esri China (Hong Kong), Esri (Thailand), TomTom, 2013, DigitalGlobe, GeoEye, i-cubed, USDA, AEX, Getmapping, Aerogrip, IGN, IGP, swisstopo, and the GIS User Community