Kimley-Horn and A					Priority: 5
Project Description	n for Unsignalized Intersection				
Client:	Town of Addison				Date: 1/2/18
Program:	ADA Self-Evaluation and Transition Plan			F	Prepared By: CMP
KHA No.:	063543021				Checked By: EPE
Corridor :	Brookwood Ln				GPS ID: 292
Project Name:	Intersection of Brookwood Ln and Aspen Ct				
Town:	Addison				
Item No.	Item Description	Quantity	Unit	Unit Price	Item Cost
	EXCAVATION (ROADWAY)	0	CY	\$ 10.00	
	CONC CURB (TY II)	0	LF	\$ 15.00	
	CONC SIDEWALKS (4")	6	SY	\$ 45.00	\$ 270.00
	CURB RAMPS	5	EA	\$ 1,500.00	\$ 7,500.00
TxDOT 5003-6002	RETROFIT DET WARN SURF (CAST IN PLACE)	0	SF	\$ 50.00	\$ -
TxDOT 104-6015	REMOVING CONC (SIDEWALKS)	21	SY	\$ 9.00	\$ 189.00
	ELIM EXT PAVE MRK & MRKS	0	LF	\$ 2.80	\$ -
TxDOT 666/678	REFL PAV MRK PREP, TY I & TY II (W) 24"(SLD)	243	LF	\$ 8.50	\$ 2,065.50
	REPAVE ROADWAY	0	LS	\$ 5,000.00	\$-
	FIX PONDING	0	LS	\$ 2,000.00	\$-
	FIX CURB RAMP TRANSITION	2	LS	\$ 2,000.00	\$ 4,000.00
	MEDIAN NOSE MODIFICATION	0	LS LS	\$ 5,000.00	
	REMOVE TEMPORARY OBSTRUCTION	0	LS	\$ 500.00	
	FIX CURB RAMP COUNTER SLOPE	0	LS	\$ 2,000.00	
Basis for Cost Proje				Subtotal	• ,
	No Design Completed			ngineering: (% +/-) 20%	
	Preliminary Design		C	ontingency: (% +/-) 20%	
	Final Design			Estimated Project Cost	: \$ 20,000.00

## Project Location



## Field Observations

Intersection Issues		Cros	swalk		Possible Solutions
		E	S	W	Possible Solutions
Path of travel pavement condition	Good	N/A	Good	Good	
Path of travel running slope is greater than 5%		N/A			
Path of travel cross slope is greater than 2% for stop control approaches	N/A	N/A	N/A		
Path of travel cross slope is greater than 5% for free-flow approaches		N/A		N/A	
Crosswalk width is less than 6'	N/A	N/A	N/A	N/A	Install crosswalk pavement markings
Crosswalk striping condition	None	N/A	None	None	install crosswalk pavement indi Milys

Curb Ramp ID ('z' or 'i' in ramp label indicates no								
Curb Ramp Issues				existing r	ramp) Possible Solutions			
	1A	2z	3z	4A				
Curb ramp does not exist and is needed		Х	Х		Install curb ramp; if median improvement, see shapefile			
Curb ramp does not land in crosswalk	I		<u> </u>	<u> </u>				
No 4' x 4' clear space at base of curb ramp								
Curbed side is not 90° or has traversable adjacent surface								
Flare cross slope is greater than 10%	Х		[	Х				
Curb ramp running slope is greater than 8.3%	Х			Х				
Blended transition running slope is greater than 5%								
Cut-thru ramp running slope is greater than 5%					Remove and replace curb ramp			
Curb ramp cross slope is greater than 2%					Achieve and replace curb famp			
Cut-thru ramp cross slope is greater than 2%								
Curb ramp width is less than 48"	Х							
Cut-thru ramp width is less than 60"			l					
Permanent obstruction (>0.25") in curb ramp/landing/flares								
Temporary obstruction (>0.25") in curb ramp/landing/flares	<u> </u>		<u> </u>	<u>i</u> i				
No textured surface at base of curb ramp	Х		<u> </u>	Х	For intersection, commercial driveway, and park ramps, install			
No color contrast at base of curb ramp	Х		İ	Х	color truncated domes			
Landing area does not exist and is needed	Х			Х	Install landing area			
Landing area is less than 5' x 5' or slopes greater than 2%	<u> </u>		<u> </u>	<u> </u>				
Curb ramp transition onto roadway is greater than 0.25"	Х		<b>_</b>	Х	Fix curb ramp transition			
Counter slope of the gutter or street at the foot of the curb ramp is								
greater than 5%								
Ponding occurs at base of curb ramp	1							

Comment: Existing sidewalk, curb ramp, and/or striping configurations permit pedestrians to cross the major street. An Engineering study is needed to confirm crossing should be accomm



Ramp 1A



Corner 3 No Ramp (3z)



Corner 2 No Ramp (2z)



Ramp 4A

## Opinion of Probable Construction Cost Disclaimer:

The Engineer has no control over the cost of labor, materials, equipment, or over the Contractor's methods of determining prices or over competitive bidding or market conditions. Opinions of probable costs provided herein are based on the information known to Engineer at this time and represent only the Engineer's judgment as a design professional familiar with the construction industry. The Engineer cannot and does not guarantee that proposals, bids, or actual construction costs will not vary from its opinions of probable costs.

## Project Location Map Sources:

Esri, DeLorme, NAVTEQ, USGS, Intermap, iPC, NRCAN, Esri Japan, METI, Esri China (Hong Kong), Esri (Thailand), TomTom, 2013, DigitalGlobe, GeoEye, i-cubed, USDA, AEX, Getmapping, Aerogrip, IGN, IGP, swisstopo, and the GIS User Community