















ISSUED FOR BID	STAGE OF PLANS	APP.
ADD - FUEL	CADD FILE NO.	DESCRIPTION
27514-000-00020		
REV.	DATE	



NOTE:  
ELEVATION OF FUEL  
FARM APPROXIMATE



TRENCH WIDTH:  $1.25B_c + 1.0'$   
WHERE  $B_c$  IS THE OUTSIDE  
DIAMETER OF THE PIPE IN FEET.



BACKFILL AROUND PIPE FLOWABLE  
FILL OR COMPACTED SELECT MATERIAL  
FROM TRENCH EXCAVATION.  
95% PROCTOR MIN. DENSITY.

1" COPPER WATER PIPE LINE SHALL BE  
COVERED IN A POLYETHYLENE SLEEVE  
OR POLY-WRAPPED

**Burns & McDonnell**  
SINCE 1935

**Washington Group International**  
Engineering and Construction  
PHONE: 800-843-2000 FAX: 800-843-2132

**Addison**  
ADDISON AIRPORT  
ADDISON, TEXAS

**BULK FUEL STORAGE AND DISPENSING SYSTEM CROSS SECTIONS & DETAILS**

DESIGNER: M.O.J.  
CADD TECH: F.J.S.

PROULEAD: S.G.L.  
CHECKERS: S.G.L./T.P.N.

APPROVED: B.D.N.