

ORDINANCE NO. 086-093

AN ORDINANCE OF THE TOWN OF ADDISON, TEXAS, AMENDING SEC. 5-37 OF CHAPTER 5 OF THE CODE OF ORDINANCES OF THE TOWN OF ADDISON, TEXAS, PROVIDING FOR FIRE DEPARTMENT INLET CONNECTIONS; PROVIDING FOR PENALTIES; PROVIDING FOR REPEAL; PROVIDING FOR SEVERABILITY; AND DECLARING AN EMERGENCY.

BE IT ORDAINED BY THE CITY COUNCIL OF THE TOWN OF ADDISON, TEXAS:

SECTION 1. That Section 5-37 of Chapter 5 of the Code of Ordinances of the Town of Addison, Texas, is hereby amended to read as follows:

Subsection 3805(f)(5)(d) is amended to read as follows:

(d) Fire Department Inlet Connections. The system shall be equipped with Fire Department Inlet Connections sized to accept no less than the minimum requirements of the automatic fire pump demand rated at 250 GPM per inlet connection. The Fire Department Inlet Connection shall be located on a street front not less than 18 inches nor more than 4 feet above grade and shall be equipped with an approved straightway check valve and substantial plug or cap.

SECTION 2. Any person, firm or corporation violating any of the provisions of this Ordinance, shall upon commission be deemed guilty of a misdemeanor, and shall be subject to a fine not to exceed the sum of Two Hundred and no/100 Dollars (\$200.00) for each offense, and each day such violation continues shall constitute a separate offense.

SECTION 3. That all ordinances of the City in conflict with the provisions of this ordinance be, and the same are hereby repealed and all other ordinances of the City not in conflict with the provisions of this ordinance shall remain in full force and effect.

SECTION 4. That should any paragraph, sentence, subdivision, clause, phrase or section of this ordinance be adjudged or be held to be unconstitutional, illegal or invalid, the same shall not affect the validity of this ordinance as a whole or any part or provision thereof other than the part so decided to be invalid, illegal, or unconstitutional.

SECTION 5. The fact that the present Code does not provide for Fire Department Inlet Connections and is therefore inadequate to properly safeguard the general public, health and safety, creates an emergency and an imperative public necessity, and the ordinance shall take effect and be in force from and after its adoption.

DULY PASSED BY THE CITY COUNCIL OF THE TOWN OF ADDISON, TEXAS, this the 28th day of October, 1986.

MAYOR 

ATTEST:

  
CITY SECRETARY