

GENERAL NOTES

- 1. CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF f'c = 3000 PSI AT 28 DAYS.
- 2. REINFORCING STEEL FY = 40 KSI.
- 3. BAR LAPS SHALL BE 30" DIAMETERS.
- 4. EXPOSED EDGES AND CORNERS TO BE CHAMPERED 3/4".

AS-BUILTS

I CERTIFY THIS PROJECT WAS CONSTRUCTED IN GENERAL CONFORMANCE WITH THESE CONSTRUCTION PLANS AND WILL FUNCTION AS DESIGNED.



· DENOTES CONCRETE REMOVAL

REV. 6-10-93 Added 27"RCP TO Junc . Box



84"RCP JUNCTION BOX DETAILS						
KMART NO.4885						
BELTLINE AND MARSH						
ADDISON,TEXAS						
AWRENCE A. CATES & ASSOC. CONSULTING ENGINEERS DALLAS, TEXAS						
ESIGN	DRAWN	DATE	SCALE	NOTES	FILE	NO.
.AC	LAC	6-4-93	"= 2 ¹ -0 ¹¹		91012	C-17