

MATCH LINE SHEET E5

MATCH LINE SHEET E7



**SHEET NOTES (SN-#):**

1. CONTROL CABLE AND POWER CABLE SHALL NOT BE INSTALLED IN THE SAME CONDUIT.
2. 2 WAY 2" CONCRETE ENCASED PVC CONDUIT (25'). SEE DETAIL SHEETS.
3. SEE DETAIL SHEETS FOR CONDUIT DETAILS AT EACH STATION.
4. SEE MALS ELECTRICAL DETAILS SHEET 1 OF 2.

LEGEND	
	JUNCTION CAN
	2" SCH 40 PVC CONDUIT (DEB)
	JUNCTION CAN PLAZA
	CONCRETE ENCASED DUCT

**WIRE NOTES (WN-#):**

1. 3-1/C #2 AWG 600V TO DISTRIBUTION PANEL.
2. 3-1/C #2 AWG 600V (RAIL POWER).
3. 6 PAIR #19 AWG 600V (RAIL CONTROL). SEE SN-1.
4. 2-1/C #4 AWG 600V (MALS POWER CIRCUITS 1 & 3).
5. 2-1/C #4 AWG 600V (MALS POWER CIRCUITS 5 & 7).
6. 3-1/C #10 AWG 600V (MALS POWER CIRCUITS 2 & 4).
- 6A. 2-1/C #10 AWG 600V (MALS POWER CIRCUIT 4).
7. 3-1/C #8 AWG 600V (MALS POWER CIRCUITS 6 & 8). SEE SN-1.
- 7A. 2-1/C #8 AWG 600V (MALS POWER CIRCUIT 8). SEE SN-1.



PROJECT NAME <b>RUNWAY 15 ESA GRADING</b>	DRAWING TITLE <b>R/W 15 PROPOSED MALS R LAYOUT - SHEET 1 OF 4</b>	DRAWING NO. <b>E4</b>	DATE <b>2/9/01</b>	REVISIONS <table border="1" style="width: 100%; border-collapse: collapse;"> <tr><th>NO.</th><th>DATE</th><th>DESCRIPTION</th></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </table>	NO.	DATE	DESCRIPTION							AUTH. <table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td> </td></tr> <tr><td> </td></tr> <tr><td> </td></tr> </table>			
NO.	DATE	DESCRIPTION															
PRELIMINARY NOT FOR CONSTRUCTION FOR REVIEW ONLY.		ANATON ALLIANCE, INC. CONSULTING ENGINEERS DATE: 2/2/01 APPROVED		FOOT NO. BID NO. E701044.00 URS NO. DESIGN DRAWN CHECKED SCALE													
<b>ADDISON AIRPORT</b> URS Greiner Woodward Clyde 4100 Armon Center Boulevard, Suite 108 Fort Worth, TX 76156 www.urscorp.com		ANATON ALLIANCE, INC. CONSULTING ENGINEERS 281-714-1888															