


- NOTE:
1. VENT DESIGN AND CONSTRUCTION SHALL BE AST MODEL VENT BY ADVANCE TANK AND CONSTRUCTION CO.
  2. VENT SHALL BE ALUMINUM WITH S.S. HARDWARE.
  3. VENT SHALL HAVE LOCKING MECHANISM TO PREVENT ACCESS TO TANK.
  4. VENT SHALL BE SCREENED WITH #16 S.S. MESH.



FREENE AND NICHOLS, INC. TEXAS REGISTERED ENGINEERING FIRM F-2144

SEAL OF THE STATE OF TEXAS  
Professional Engineer  
RONALD G. KING  
81073  
1-19-11  
Freen and Nichols

**FREENE AND NICHOLS**  
2220 San Jacinto Blvd., Suite 330  
Houston, TX 77002-4800  
Phone: (840) 387-4800  
Fax: (840) 387-4677  
Web: www.freenenichols.com

TOWN OF ADDISON, TEXAS  
SURVEYOR 1.5 MG EST  
CIVIL  
TANK DETAILS

NO.	ISSUES	DATE	BY	DATE	F&N JOB NO.	FILE NAME
					ADD08459	CV-EST-DT-TYP03.SHT

DESIGNED: DAT  
DRAWN: SB  
REVISION: RUS  
CHECKED: RJK  
VERIFY SCALE Bar is one inch on original drawing. If not one inch on this sheet, adjust scale.

SHEET DT-03

CV-EST-DT-TYP03.SHT  
34border.dgn  
MicroStation V8 User:amr Office: Denton  
DD08459  
Plot Scale: 0.125" = 1'-0"  
Date: 01/19/2011 - 01:58:33 PM Project: Freen and Nichols, Inc.