

VALVE BOX AND LID

ells as part of this contract.

be permanent and waterproof.

Schedule 40. Sizes as indicated on plans.

with the intent of the plans and specifications.

6. AUTOMATIC CONTROLLER shall be installed at location shown. Power

(120V) shall be located in a junction box within five feet (5') of controller

7. All 24 voit valve wiring is to be UF 14 single conductor. All wire splices are to

pressure. If static pressure is less than 50 PSI, do not start work until notified

8. SLEEVES shall be installed by General Contractor. Sleeve material shall be

9. Ten days prior to start of construction, contractor shall verify static water

10. All mainline and lateral piping shall have a minimum of 12 inches of cover. All

11. The irrigation contractor shall coordinate installation of the system with the

landscape contractor so that all plant material will be watered in accordance

to insure 100% and proper coverage of all lawn areas and plant material. All

nozzles in parking lots and planting beds shall be low angle to minimize overspray on

12. The irrigation contractor shall select the proper arc and radius for each nozzle

piping under paving shall have a minimum of 18 inches of cover.

pavement surfaces. No water will be allowed to spray on building.

- GEAR DRIVEN MOTOR AS SPECIFIED

WATER METER (AS SIZED) BACKFLOW PREVENTER (AS SIZED) CLASS 200 PVC LATERAL PIPING -----CLASS 200 PVC MAINLINE SCH. 40 PVC SLEEVING (AS SIZED) ____

RECORD DRAWINGS: THE INTENT OF THE OWNER AND ENGINEER WAS TO CONSTRUCT THESE FACILITIES ACCORDING TO THESE PLANS AS APPROVED BY THE CITY OF ADDISON. THE LINES AND GRADES WERE SET ON THE GROUND FOR CONSTRUCTION ACCORDING TO SAID PLANS. THE CITY OF ADDISON INSPECTED THE CONSTRUCTION. NEITHER THE OWNER NOR THE ENGINEER VERIFIED LINES OR GRADES AFTER CONSTRUCTION WE ARE NOT AWARE OF ANY CHANGES OR REVISIONS TO THESE PLANS DURING CONSTRUCTION. EXCEPT AS NOTED 1

JAN 3, 2002

JOB NO. SHEET NO.

PROJECT MGR.

PROJECT TECH.

CHECKED BY