



**METER VAULT**

ALL METERS AND DOUBLE CHECKS IS ONE BOX - LARGE ENOUGH TO ALLOW COMPLETE ACCESS FOR REPAIRS USE A Bilco TYPE Lid - VAULT NEEDS TO BE CONCRETE WITH CONCRETE FLOOR.

METERS AND F.H. MUST BE RELOCATED TO TOWN APPROVED LOCATION. NOTE: NO VALVE OR GOS BEWD EXIST

This has been moved to west

SEE METER VAULT DETAIL

Seal req'd

WATER & SANI. SWR. PLAN						
OFFICE DEPOT						
ADDISON, TEXAS						
<b>BROCKETTE DAVIS DRAKE, inc.</b> consulting engineers Civil & Structural Engineering - Surveying 3535 Travis, Suite 100 • Dallas, Texas 75204 • (214) 522-9540						
design	drawn	date	scale	notes	job no.	sheet no.
M.M.W.	BJS	2-7-91	1" = 30'	E.H.	C90302	<b>C2</b>

BENCH MARKS:  
 SQUARE CUT ON NORTHEAST CORNER OF CONCRETE VAULT IN THE NORTHEAST CORNER OF THE INTERSECTION OF BELT LINE RD. AND ADDISON RD. ELEV. 634.20  
 SQUARE CUT ON 10' INLET WEST SIDE OF QUORUM DR. LOCATED A DISTANCE OF 340' +/- NORTH OF THE NORTH LINE OF BELT LINE RD. ELEV. 641.53