



**UTILITY LEGEND**

- PROPOSED 2.5" DOMESTIC WATER SERVICE
- PROPOSED 6" FIRE WATER SERVICE MAIN
- PROPOSED 4" SANITARY SEWER LINE
- PROPOSED 1500 GAL GREASE INTERCEPTOR
- PROPOSED STORM DRAIN CLEANOUT
- PROPOSED LANDSCAPED AREA CATCH BASIN
- PROPOSED 4" STORM DRAIN LINE (LANDSCAPED AREAS ONLY)
- PROPOSED 6" STORM DRAIN LINE (LANDSCAPED AREAS ONLY)
- PROPOSED 12" STORM DRAIN LINE
- LIMIT OF WORK / DISTURBANCE
- INVERT
- POLYVINYL CHLORIDE PIPE
- HDPE
- HIGH DENSITY POLYETHYLENE PIPE

**UTILITY NOTES**

1. CONTRACTOR IS RESPONSIBLE FOR BIDDING ALL UTILITY WORK SHOWN ON THIS PLAN THAT FALLS OUTSIDE AS WELL AS INSIDE THE LIMIT OF WORK/DISTURBANCE LINE. **NO CHANGE ORDERS WILL BE ACCEPTED OR APPROVED FOR FAILURE TO INCLUDE THESE ITEMS.**
2. CONTRACTOR SHALL PORTHOLE AND FIELD VERIFY ALL UTILITY POINTS OF CONNECTION AND EXISTING FACILITIES PRIOR TO THE START OF CONSTRUCTION AND ORDERING/PURCHASE OF MATERIALS FOR THE PROJECT. ANY CONFLICTS SHALL BE BROUGHT TO THE OWNER & ENGINEER'S ATTENTION FOR RESOLUTION.
3. CONTRACTOR SHALL TAKE NECESSARY MEASURES TO PROVIDE UNINTERRUPTED SERVICE OF ALL UTILITIES TO THE SITE (AS APPROPRIATE) AND ESPECIALLY TO ADJACENT TENANTS DURING CONSTRUCTION.
4. CONTRACTOR SHALL FIELD VERIFY EXISTING SANITARY SEWER FACILITIES SERVING ADJACENT BUILDINGS AT THE BACK OF BUILDING SERVICE DRIVE PRIOR TO START OF CONSTRUCTION. VERIFY EXISTING 6" SANITARY SEWER LOCATION, DEPTH AND CONDITION. CONTRACTOR SHALL ADJUST WITH OWNER AND ENGINEER APPROVAL. PROPOSED LOCATION(S) OF SANITARY SEWER PIPES, CLEANOUTS, GREASE INTERCEPTOR AND APPURTENANCES IN ORDER TO MAKE CONNECTION TO EXISTING SANITARY SEWER FACILITIES. VOP'S PROJECT MANAGER SHALL ALSO BE NOTIFIED IF CHANGES ARE MADE TO THE LOCATION OF THESE STRUCTURES.
5. CONTRACTOR SHALL FIELD VERIFY EXISTING STORM DRAINAGE FACILITIES AT THE TWO POINTS OF CONNECTION PRIOR TO START OF CONSTRUCTION. ANY CONFLICTS SHALL BE BROUGHT TO THE OWNER & ENGINEER'S ATTENTION FOR RESOLUTION.
6. ALL WATER, SEWER, AND STORM DRAIN CONSTRUCTION SHALL BE IN CONFORMANCE WITH CITY OF ADDISON STANDARDS AND SPECIFICATIONS AND 2012 INTERNATIONAL PLUMBING CODE.
7. DOMESTIC WATER SERVICE AND FIRE SERVICE WATER LINES WILL BE COLOCATED IN ONE TRENCH. MINIMUM DEPTH OF BURY ON THE 6" FIRE SERVICE SHALL BE 4.0 FT. PER CITY OF ADDISON STANDARDS AND SPECIFICATIONS.
8. CONTRACTOR MAY ADJUST THE LOCATIONS OF LANDSCAPE AREA DRAINS SUCH THAT THEY ARE INSTALLED IN THE MOST

