


SECONDARY SERVICE FROM PADMOUNTED TRANSFORMER FOR CATV

212 - 315

1 PHASE, 2 WIRE, 120V METER INSTALLATION



- NOTES:

 1. METER SOCKET INSTALLED BY CUSTOMER. CUSTOMER TO MAKE ALL SERVICE CONDUCTOR CONNECTIONS.

 2. ALL RACEWAY (CONDUIT, HARDWARE, ACCESSORIES, ETC.) SERVICE ENTRANCE CONDUCTORS, PROVIDED AND INSTALLED BY CUSTOMER. RACEWAY AND SERVICE LATERAL CONDUCTORS TO BE FURNISHED AND INSTALLED BY CUSTORMER. RACEWAY FOR SERVICE LATERAL CONDUCTORS TO BE MINIMUM OF 2 INCH APPROVED SCHEDULE 40 PVC.

 3. POLE TO BE A MINIMUM OF 3 INCH RIGID GALVANIZED STEEL PIPE AND CONCRETE BACKFILLED. POLE LOCATION TO BE APPROVED BY TUELECTRIC.

 4. CUSTOMER TO PROVIDE AND INSTALL 8 FT. GROUND ROD AND AT MINIMUM A #6 SOLID BARE CJ. GROUND WIRE.

 5. CUSTOMER TO PROVIDE AND INSTALL 8 FT. GROUND ROD AND AT MINIMUM A #6 SOLID BARE CJ. GROUND WIRE.

 6. CUSTOMER TO PROVIDE AND INSTALL 8 FT. GROUND ROD AND AT MINIMUM A #6 SOLID BARE CJ. GROUND WIRE.

 7. SUSTEMBLY SUPPLY SUPPLIED TO THE ACCORDING TO THE APPROVED BY TUELECTRIC.

- 6. INSTALLATION TO BE ACCORDING TO THE NATIONAL ELECTRICAL CODE. INSPECTION AUTHORITY APPROVAL REQUIRED IN INSPECTION LIMITS.

ITEM	QTY	DESCRIPTION	TSN/ REF	CU	MU
1		TRANSFORMER	209-210,211		
2		PAD, TRANSFORMER, 44" X 56"	205-155		1
3		CONNECTOR, SECONDARY	212-105		

APPROVED BY TUELECTRIC





FIRM REGISTRATION NUMBER: 312



TOWN OF ADDISON DALLAS COUNTY, TEXAS

> BELT LINE ROAD UNDERGROUND ELECTRICAL

SPLICE/ PULL BOX **INSTALLATION DETAIL**

HALFF 1201 NORTH BOWSER ROAD, RICHARDSON, TEXAS 75081-2275 TEL (214) 348-8200 FAX (214) 739-0095									
PROJECT	DESIGN	DRAWN	DATE	FILE	SHEET				
29350	HALFF	HALFF	OCT. 2013	29350 ELEC 29d	ELE-29				