

COPYRIGHT 2013 ONCOR ELECTRIC DELIVERY COMPANY. ALL RIGHTS RESERVED.

PRECAST VAULT FOR SF6 DEAD FRONT **SWITCHGEAR**


ALL DIMENSIONS SHOWN ARE MINIMUM INSIDE MEASUREMENTS. CONTACT DISTRIBUTION STANDARDS FOR ACTUAL MFG. DIMENSIONS.

5. VAULTS SHALL NOT BE INSTALLED IN LOCATIONS DESIGNATED ACCESSIBLE BY VEHICULAR TRAFFIC.
6. ADJUSTABLE SWITCHGEAR PLATFORM FOR 4-6 WAY SWITCHGEAR.
7. FOR CLEARANCES ON ALL SIDES OF THE SWITCHGEAR SEE DETAIL SHEETS 1, 2, 3 & 4.
8. TWO 5'8" X 10' COPPER CLAD GROUND RODS TO BE OBTAINED AND INSTALLED BY CONTRACTOR.
9. CONTACT COMPANY REPRESENTATIVE FOR VAULT ORDERING INFORMATION.

2. LADDER, PLATFORMS, SUPPORT ANGLES AND COVER ARE PRE-INSTALLED.

3. STEEL DIAMOND PLATE TORSION ASSISTED COVERS.

4. VERTICAL LOADS TO COVER SHALL NOT EXCEED 16,000 LBS LIVE WHEEL WEIGHT.




04 - 13

.P.E. 10-24-13 Signature of Registrant

9

FIRM REGISTRATION NUMBER: 312



BELT LINE ROAD

UNDERGROUND ELECTRICAL

HALFF 1201 NORTH BOWSER ROAD, RICHARDSON, TEXAS 75081-2275 TEL (214) 349-8200 FAX (214) 739-0095					
PROJECT	DESIGN	DRAWN	DATE	FILE	SHEET
29350	HALFF	HALFF	0CT. 2013	29350 ELEC 25d	ELE-25



APPROVED BY ONCOR

NOTE 6

6" TERMINATOR— AT 16" ON CENTER. (TYPICAL)

NOTE;

PULLING EYE --(20,000 LBS MIN.)

NOTE 7

DCS-5 DETAIL SHEET 18 OF 19

TOWN OF ADDISON DALLAS COUNTY, TEXAS

ONCOR DUCT BANK DETAIL 4E6