KEY NOTES:

1. NOT USED.
2. PROVIDE 2#8,1#10G IN 2"C TO NEAREST UTILITY TRANSFORMER. #8 IS CALCULATED FOR 1000' LENGTH @480V,1PH. FOR LONGER LENGTHS A HIGHER CABLE SIZE IS REQUIRED.
3. NOT USED.
4. REPLACE EXISTING STREET LIGHT AND EXISTING WIRING WITH NEW POLE LIGHTS AND NEW WIRING.
5. EXISTING TRAIL LIGHTS TO REMAIN.
6. EXISTING STREET LIGHTS TO REMAIN.

1 TRAIL CONNECTION – PHASE 2

SCALE: 1" = 40'-0"

JSE
JORDAN & SKALA ENGINEERS
17855 North Dallas Parkway, Suite 320
Dallas, TX 75287
V: (469) 385-1616 F: (469) 385-1615

STATE OF TEXAS
MARK N. BIGBIE
83876
LICENSED
PROFESSIONAL ENGINEER
11/17/14

THIS DRAWING IS THE PROPERTY OF JORDAN & SKALA ENGINEERS INC. AND IS NOT TO BE REPRODUCED IN WHOLE OR IN PART WITHOUT WRITTEN PERMISSION BY JORDAN & SKALA ENGINEERS.

ADDISON PEDESTRIAN CONNECTION PH 2 & 3

ADDISON, TEXAS

PRINT RECORD

DATE	ISSUED FOR
5/21/2014	REVIEW SET
06/23/14	50% REVIEW SET
07/30/14	90% CD
08/18/14	95% CD
09/17/14	CHECK SET
09/29/14	100% BID DOCUMENT

REVISIONS

#	DATE	DESCRIPTION

Project Number: 143-0340

Drawn By: VB Checked By: MNB

SHEET TITLE

ELECTRICAL - POWER

SHEET NUMBER

E1.01

NOT ISSUED FOR CONSTRUCTION