


**NOTES**

1. The Town of Addison shall shut down existing waterlines during off-peak hours.
2. Excavate and remove existing gate valves, including pavement removal.
3. Install new gate valve, including valve stack furnished to the site by the Town of Addison.
4. Restore area with solid sod.
5. Place 10-Inch reinforced concrete pavement and curb. NCTCOG Item 745, Class "C" concrete; 3600 psi compressive strength @ 28-days, minimum 6-sack mix per cubic yard. Maximum water cement ratio 6.0.
6. Backfill shall be select material (NCTCOG Item 2.1.8(c) compacted in place.
7. Embedment shall be NCTCOG Grade 4 aggregate to spring line of pipe.

**FURNISH & INSTALL**  
 4" OR 6" x 1" TAP  
 5 L.F. - 1" TYPE K COPPER WATERLINE  
 1-1" CURB STOP-6" BELOW SURFACE  
 1-1" CORP STOP W/COMP NUT  
 1-CONC. METER BOX & COVER (10" x 20")

**SCALE 1":100**



**LEGEND**

	16" Water Line (Size Indicated)
	Fire Hydrant W/Valve
	Fire Hydrant No Valve
	Meter Station
	Valve
	Reducer

WATER

---

TOWN OF  
ADDISON

Rev.	
SHEET 5	

3	8
4	9
5	10

SHEET INCL X