



REMOVE & REPLACE VALVE 18M19

1. The Town of Addison shall shut down existing waterlines during off-peak hours.
2. Excavate and remove existing gate valves, including pavement removal.
3. Install new gate valve, including valve stack furnished to the site by the Town of Addison.
4. Restore area with solid sod.
5. Place 10-Inch reinforced concrete pavement and curb. NCTCOG Item 745, Class "C" concrete; 3600 psi compressive strength @ 28-days, minimum 6-sack mix per cubic yard. Maximum water cement ratio 6.0.
6. Replacement of valve 18M19 shall occur between the hours of 10:00 p.m. 5:00 a.m. Water service to the Greenhill School will need to be shut down during this period.
7. Backfill shall be select material (NCTCOG Item 2.1.8(c) compacted in place.
8. Embedment shall be NCTCOG Grade 4 aggregate to spring line of pipe.

SHUT OFF VALVE

GREENHILL SCHOOL

SCALE 1"=100

WATER

Rev. _____

SHEET 6

LEGEND

	12" Water Line (Size Indicated)
	Fire Hydrant w/Valve
	Fire Hydrant No Valve
	Meter Station
	Valve
	Reducer

18

7	17	26
8	18	27
9	19	28