



Sta. 0+03.89 Remove Existing Dished Head Plug\* Continuous Weld 30" Spigot by 30" Flanged Spool to Existing 30" Outlet. Install 30" B.F.V. Install 30" Flanged by 42" Bell Reducer.

PLAN  
1" = 20'

PROFILE  
Horiz. 1" = 20'  
Vert. 1" = 4'

PLAN  
1" = 20'

PROFILE  
Horiz. 1" = 20'  
Vert. 1" = 4'

- NOTES:
- \* 1. Salvage 30" & 48" Dishhead Plugs And Deliver To City Storage Yard At 2900 Municipal St.
  - 2. Type 1 Air Valve Installation. See Appurtenance Sheet 4140-11

B.M. - cut on S.E. corner of Pump Pits Structure behind Pump House @ Beltwood Pump Station Elev. 630.02.

|   |                           |
|---|---------------------------|
| 4/3/81 (1) Added Note (Or Steel Pipe)   | W.E.M.                    |
| DATE                                    | BY                        |
| <b>42" BYPASS LINE PLAN AND PROFILE</b> |                           |
| <b>PUMPS 1A &amp; 2A</b>                |                           |
| <b>BELTWOOD PUMP STATION</b>            |                           |
| <b>DALLAS WATER UTILITIES</b>           |                           |
| <b>CITY OF DALLAS, TEXAS</b>            |                           |
| DESIGN <u>R.O.J., E.H.H.</u>            | CONTRACT NO. <u>81-7</u>  |
| DRAWN <u>B.K., L.M., W.E.M.</u>         | FILE NO. <u>640Q-700B</u> |
| TRACED _____                            | DATE <u>DEC 80</u>        |
| CHECKED _____                           | SHEET NO. <u>2</u>        |
| DATE _____                              | OF <u>20</u>              |

