



**NOTE:**

1. ALL ON-SITE WATER LINES ARE 8" DIAMETER PVC.
2. ALL ON-SITE SANITARY SEWER LINES ARE 8" DIAMETER PVC.
3. ALL LOTS HAVE A 2-INCH DIAMETER WATER LATERAL TO MAIN LINE IN STREET
4. ALL LOTS HAVE A 4-INCH DIAMETER SEWER LATERAL TO MAIN LINE IN STREET

**LEGEND:**

- PROPOSED FIRE HYDRANT WITH TEE AND 6-INCH VALVE
- PROPOSED SANITARY SEWER MANHOLE
- PROPOSED SANITARY SEWER CLEANOUT
- EXISTING SANITARY SEWER MANHOLE

| NO. | REVISION | BY | DATE |
|-----|----------|----|------|
|     |          |    |      |
|     |          |    |      |
|     |          |    |      |
|     |          |    |      |

DESIGNED BY: *L. Hudson*  
 DRAWN BY: *L. Hudson*  
 CHECKED BY: *L. Hudson*  
 SCALE: 1" = 100'  
 DATE: NOVEMBER 1984

**eh** ESPEY, HUSTON & ASSOCIATES, INC.  
 Engineering & Environmental Consultants  
 333 W. Campbell Rd. Richardson, Texas 75080  
 (214) 669-9600

PRELIMINARY  
 WATER AND SANITARY SEWER PLAN  
**BELLBROOK ESTATES**  
 ADDISON, TEXAS  
 FOR  
 THE SHARIF-MUNIR-DAVIDSON DEVELOPMENT CORP

SHEET NO. **2**  
 OF **2** SHEETS  
 JOB NO. **5676**