


CONTINUED PANEL LEFT

CONTINUED PANEL LEFT



CONTINUED PANEL RIGHT

NOTES THIS SHEET

1. THIS SHEET SHOWS CONTROL LOGIC WIRING ONLY FOR THE CELESTIAL ROAD PUMP STATION CONTROL PANEL. PUMP ALTERNATION SHALL BE DONE BY THE PROGRAMMABLE CONTROLLER. JUMPER FUTURE PUMP SKIP INPUTS TO PROGRAMMABLE CONTROLLER IN TUNNY ALTERNATES ONLY THREE PUMPS. PROVIDE TERMINAL STRIPS FOR ADDITION OF FUTURE CONTROL UNITS SUCH AS SELECTOR SWITCHES & LIGHTS...

2. SUBMIT SHOP DRAWINGS SHOWING ALL OTHER WIRING FOR THE ANNUNCIATORS, TELEMETRY, INSTRUMENT LOOP WIRING, ETC. FOR ALL MAIN & LOCAL CONTROL PANELS. ALL FIELD WIRING SHALL HAVE TERMINAL STRIPS. ALL ANNUNCIATOR & TELEMETRY INPUTS & OUTPUTS SHALL HAVE TERMINAL STRIPS.


3. THE CONTROL PANEL FOR THE SECURITY SYSTEM SHALL BE LOCATED IN THE MAIN CONTROL PANEL AT CELESTIAL ROAD & IN THE LOCAL PANEL AT THE SUBVENTOR ROAD PUMP STATION.

4. EACH CONTROL PANEL SHALL HAVE A CIRCUIT BREAKER DISCONNECT FOR THE INCOMING POWER AND THE UPS. FURNISH SQUARE D TYPE 60 AMP BREAKERS MOUNTED ON THE INSIDE & MOUNTED MAIN PANEL DISCONNECT AND UPS OUTPUT DISCONNECT.

LEGEND

- ▲ DEVICE REMOTE FROM CONTROL PANEL
- DEVICE MOUNTED ON FRONT OF CONTROL PANEL
- LOR-SS LOCAL-OFF-REMOTE SELECTOR SWITCH

APPENDUM NO. 1 - NEW DRAWING		JK	13-20-1971
No.	Revision	By	Date
TOWN OF ADDISON DALLAS COUNTY, TEXAS <b>CELESTIAL ROAD PUMP STATION</b>			
CHARLES R. MCGREARY & ASSOCIATES CONSULTING ENGINEERS SUITE 217 6300 LBJ FREEWAY DALLAS, TEXAS 75240		INSTRUMENTATION CONTROL PANEL SCHEMATICS	
<b>GINN, INC.</b> Consulting Engineers Dallas, Texas			
Designed - JK	Drawn - JW	Date -	Job No. -
Approved -	Checked -	Scale -	Sheet I-4 of



Joseph J. Kotrla  
3-11-87