



- LEGEND**
- ⊕ SECURITY LIGHT
  - ⊕ CEILING LIGHT
  - ⊕ SUSPENDED CEILING LIGHT
  - ⊕ OVER THE SINK LIGHT
  - ⊕ COACH LIGHT
  - ⊕ RECESSED CAN LIGHT
  - ⊕ RECESSED DIRECTIONAL CEILING LIGHT
  - ⊕ 2' - ONE TUBE FLOURESCENT LIGHT
  - ⊕ 110 DUPLEX OUTLET
  - ⊕ WEATHER PROOF OUTLET
  - ⊕ 220 OUTLET
  - ⊕ GROUND FAULT CIRCUIT INTERRUPTER
  - ⊕ SWITCH
  - ⊕ THREE-WAY SWITCH
  - ⊕ PHONE
  - ⊕ TELEVISION
  - ⊕ EXHAUST VENT (OPT.)
  - ⊕ THERMOSTAT
  - ⊕ 2X4 FLOURESCENT LIGHT
  - ⊕ SMOKE DETECTOR
  - ⊕ CEILING MOUNTED EXHAUST FAN

**NOTE:** All electrical work is to be done in accordance with NEC and all local codes. All electrical work is to be performed by qualified craftsmen. All electrical components are to be new and fully functional. Minimum wire size allowed for 120 volt is 12 gage, no splices. Conduit will be sized (min. 25% oversized) and installed as required. Panel boxes will be properly sized and installed as needed. All electrical work is to be coordinated with the structural, HVAC, painter's, etc. work. These drawings reflect the basic intent of the project, however, if in doubt, contact the supervisor on this project for verification of the required outcome. All electrical components and labor shall be guaranteed for a minimum of one year.

**NOTE:** Exterior walls shown 4" thick Interior walls are 4 1/2" thick

**NOTE:** Each restroom to have instant hot water heater HVAC and Janitor space to be provided Refer to Dwg E-3 for Hangar electrical needs

**SECOND FLOOR ELECTRICAL PLAN**

**ADDISON EXPRESS HANGER ADDITION**  
4500 Claire Chemnaut  
Addison, Texas

**OFFICE AREA**  
1st & 2nd ELECTRICAL PLAN  
Scale 1/4" = 1'-0"

**WECO ENGINEERING CO**  
406 Erie Street  
Cleburne, Texas 76031  
(817) 645-1160

REV.	DATE	DESCRIPTION

DWG NO: addisonE

**E-2**

DATE: 06-22-80