



- LEGEND
- ⊗ = SECURITY LIGHT w/ PHOTOEYE
 - ⊞ = CEILING LIGHT
 - ⊞ = COACH LIGHT
 - ⊞ = HID BAY LIGHT
 - ⊞ = RAPID START FLOOD LIGHT
 - ⊞ = 110 DUPLEX OUTLET
 - ⊞ = WEATHER PROOF OUTLET
 - ⊞ = SPECIAL OUTLET
 - ⊞ = DOOR OPERATOR MOTOR
 - ⊞ = SWITCH
 - ⊞ = THREE-WAY SWITCH
 - ⊞ = PHONE

NOTE: All electrical work is to be done in accordance with NEC and all local codes.
 All electrical work is to be performed by qualified craftsmen.
 All electrical components are to be new and fully functional.
 Minimum wire size allowed for 120 volt is 12 gage, no splices.
 Conduit will be sized (min. 25% oversized) and installed as required.
 Panel boxes will be properly sized and installed as needed.
 All electrical work is to be coordinated with the structural, HVAC, painter's, etc. work.
 These drawings reflect the basic intent of the project, however,
 if in doubt, contact the supervisor on this project
 for verification of the required outcome.
 All electrical components and labor shall be guaranteed for a minimum of one year.

ADDISON EXPRESS
 HANGER ADDITION
 4500 Claire Chennault
 Addison, Texas

HANGER AREA
 ELECTRICAL & LIGHTS

WECO ENGINEERING CO
 406 Erie Street
 Cleburne, Texas 76031
 (817) 645-1160

REV.	DATE	DESCRIPTION

DWG NO. addison

E-3

DATE: 05-27-00

SCALE 1/8" = 1'-0"