1. Fire Lanes to Town of Addison F.D.'s specs (min. 24' width; 13'6" overhead clearance)

2. Fire extinguishers per placement code

occ. class	travel distance	square feet
B-3	75'	6,000 sq ft
H-5	50'	3,000 sq ft

where are exits from this hanger?

FIRE LANE

FIRE LANE

FIRE LANE

TYPICAL DRIVEWAY SECTION

SITE DRAINAGE PLAN

CITY OF ADDISON
BUILDING INSPECTION DEPARTMENT

SITE DRAINAGE HANGER NO. 2

MISSION AIRE FACILITY
ADDISON AIRPORT ADDISON, TEXAS

DATE OF PERMIT | JOB NO. 2-84-01

REVISIONS

DONALD E. DAVIS CONSULTING ENGINEERS