

1'-0"

- & BEAM •3

1.56 %

EXIST. REBAR (TYP.)

7'-21/2"

E BEAM •2

THICKENED SLAB END REMOVAL DETAIL

SCALE: 1/4" -1'-0"

BREAKBACK LINE (PARALLEL TO ROADWAY SURFACE) =

7'-21/2"

BEAM *1

CONSTRUCTION NOTES:

- CONTRACTOR MUST PROVIDE ADEQUATE MEANS OF PROTECTING THE EXISTING BRIDGE FROM DAMAGE DURING REMOVAL STAGE.
- 2. CONTRACTOR MUST SUBMIT REMOVAL PLAN FOR APPROVAL BY THE ENGINEER. THE REMOVAL PLAN SHALL INCLUDE DETAILS SHOWING PROTECTION FOR ALL STRUCTURES, APPURTENANCES AND PEDESTRIAN/VEHICULAR TRAFFIC. ADDITIONALLY, THE PLAN SHALL DESCRIBE REMOVAL MEANS AND METHODS THAT WILL PROTECT THE INTEGRITY OF THE EXISTING STRUCTURE.
- 3. INTERIOR DIAPHRAGMS TO REMAIN IN PLACE DURING THE REMOVAL PHASE, UNLESS ADDITIONAL BRACING IS PROVIDED. BRACE EXTERIOR BEAM DURING THE SLAB REMOVAL AND REPLACEMENT PROCESS. FOR ADDITIONAL INFORMATION, SEE TXDOT STANDARD DRAWING "MINIMUM ERECTION AND BRACING REQUIREMENTS", MEBR (C). AFTER STAGE 1 REMOVAL CONTRACTOR MUST VERIFY THAT EXISTING BEAMS REMAIN PLUMB PRIOR TO PLACEMENT OF PROPOSED BRIDGE SLAB.
- 4. ALL APPURTENANCES (INCLUDING TRAFFIC SIGNALS, ILLUMINATION, ETC.), WITHIN THE WORK ZONE, SHALL REMAIN IN OPERATION AND PROTECTED FROM DAMAGE DURING CONSTRUCTION. SEE TRAFFIC CONTROL PLAN FOR ADDITIONAL INFORMATION.
- 5. REMOVE 3" OF EXIST. CONCRETE OR TO TOP OF PRECAST PANEL, WHICHEVER IS LESS. CONTRACTOR TO USE CARE NOT TO DAMAGE EXIST. REINFORCEMENT, PRECAST PANEL OR CONCRETE TO REMAIN IN PLACE. ANY PORTION DAMAGED BY THE CONTRACTOR SHALL BE REPLACED BY THE CONTRACTOR AT THE CONTRACTOR'S EXPENSE. ANY REINFORCING STEEL DAMAGED, CUT OR BROKEN BY THE CONTRACTOR'S OPERATIONS OR WITH SECTION LOSS DUE TO CORROSION GREATER THAN 25% SHALL BE RESTORED WITH NEW BARS OF THE SAME SIZE BY LAPPING OR WELDING AS DIRECTED BY THE ENGINEER.
- 6. ALL NEW REINFORCING TO BE EPOXY COATED.
- 7. APPLY TYPE V EPOXY ADHESIVE, CONFORMING TO DMS-6100, TO ALL EXPOSED SURFACES ALONG BREAK LINES PRIOR TO PLACING NEW CONCRETE.
- 8. CONTRACTOR MAY SPLICE EXISTING BRIDGE SLAB
 REINFORCING BY LAP SPLICE OR USING MECHANICAL
 COUPLING DEVICES (IN ACCORDANCE WITH CURRENT
 SPECIAL PROVISION (440-005) TO ITEM 440,
 "REINFORCING STEEL"). THE COUPLER SHALL DEVELOP
 IN TENSION AT LEAST 125% OF THE SPECIFIED YIELD
 STRENGTH OF THE REINFORCING BAR. IN AREAS WHERE
 SPLICE/COUPLING CANNOT BE USED, THE CONTRACTOR
 SHALL USE RESIN ANCHORED DOWEL BARS AS
 APPROVED BY THE ENGINEER.



REMOVAL NOTES

1.56 %

& BEAM +3

-⊈ BEAM •2

THICKENED SLAB END REPLACEMENT DETAIL

SCALE: 1/4"-1'-0"


7'-21/2"

SPLICE BARS G TO EXIST. REBAR, AS APPROVED BY THE

CTRS. (TYP.) (FIELD BEND)

7'-21/2"

- 1 HATCHED AREA INDICATES PORTION OF EXIST. BRIDGE DECK TO BE REMOVED.
- 2 EXISTING TOP LONGITUDINAL REBAR TO BE REMOVED FLUSH WITH BREAKBACK LINE.
- (3) CLEAN AND STRAIGHTEN EXISTING REINFORCING STEEL A MINIMUM OF 2'-8" INTO NEW CONSTRUCTION.
- (4) PRIOR TO BREAKING BACK OF EXISTING STRUCTURE, SAWCUT A VERTICAL JOINT AT A DEPTH OF 1/2" FULL LENGTH OF SLAB ALONG REMOVAL LINE.



DALLAS NORTH TOLLWAY



DECK REPLACEMENT DETAILS

VERDE VALLEY LANE OVERPASS
SHOULDER REPLACEMENT

SHEET 4 OF 5

PBS

STM 4 & 5 PLAN SET A DESIGNED __DWS__DATE_03-21-05

DRAWN TLH OATE 03-21-05 CESCRED DWS DATE 03-21-05
CONTRACT NO. 02040-DNT-02-CN-EN SHEET A164 OF A200

9/30/2005 12,27,29 p

TYPE C BEAM (TYP.)

2'-111/2"