



North Arrow
 SW corner of town site at 643.50
 SW corner of town site at 643.50



BROCKETTE/DAVIS/DRAKE, INC.
 CONSULTING ENGINEERS
 12345 DALLAS, TEXAS 75201
 TEL: 214-555-1234

Note:
 1. All water mains shall be 30" SDR-18 water pipe (1/4" brace with wire tracers).
 2. All water mains shall have minimum cover below finished grades as follows:
 6" & 8" - 48" or as required to clear other utilities.
 Sanitary Sewer laterals to existing Sanitary Sewer main shall be installed
 by contractor.
 All trench backfill for utilities shall be compacted as required by city.
 All fire hydrants shall be set 3' to 6' from curb.
 All fire hydrants to be set 3' to 6' from curb.

GENERAL NOTES
 1. All water mains shall be 30" SDR-18 water pipe (1/4" brace with wire tracers).
 2. All water mains shall have minimum cover below finished grades as follows:
 6" & 8" - 48" or as required to clear other utilities.
 Sanitary Sewer laterals to existing Sanitary Sewer main shall be installed
 by contractor.
 All trench backfill for utilities shall be compacted as required by city.
 All fire hydrants shall be set 3' to 6' from curb.
 All fire hydrants to be set 3' to 6' from curb.



Scale: 1" = 30'

C4 Sheet of 3 Date: 01/18/01	Project: Marriott QUORUM 12 STORY TOWER 1788 ADDISON, TEXAS	Bogard Haldeman Miller Registered Professional Engineer State of Texas No. 12345 Dallas, Texas 75201 214-555-1234
	Title: WATER & SEWER PLAN	