



GENERAL NOTES - SITE UTILITIES

- 1) ALL MATERIAL, EQUIPMENT, INSTALL, TESTING & APPROVALS AS PER CITY OF ADDISON & NFPA.
- 2) ALL PIPE TO BE PLACED ON 4" SAND BASE w/ 1'-0" SAND ABOVE PIPE. AFTER VISUAL INSPECTION & HYDRO TEST AS PER CITY, BACK FILL AS PER CITY, DEPTH OF BACKFILL NOT TO EXCEED 5 FT.
- 3) ALL PVC TO BE CLASS 250 SDR 15, ALL DUCTILE IRON TO BE D150.
- 4) ALL FITTINGS & LARGER TO BE N.S. 4 AND.

IMPORTANT
In facilities subject to freezing conditions, it is the owner's responsibility to provide heat throughout wet side sprinkler systems areas and water supplied to sprinkler systems. This drawing and the information and design application herein are provided for informational purposes only and do not constitute a contract. The user of this drawing and the information and design application herein is responsible for the reproduction of this drawing or any part thereof shall be made without the written consent of GFS.

CONTRACT RESPONSIBILITIES		COORDINATION RECORD		MATERIAL REQUIRED		SPRINKLERS		FITTINGS		APPROVALS	
ITEM	DESCRIPTION	DATE	BY	ITEM	DESCRIPTION	TYPE	QTY	ITEM	DESCRIPTION	DATE	BY
1	STREET WATER CONNECTION			1	INTERIOR	TYPE	QTY	1	4" CLASS 250 SDR 15 PVC		
2	UNDERGROUND WATER MAINS			2	UNDERGROUND	TYPE	QTY	2	4" CLASS 250 SDR 15 PVC		
3	BACKFILL			3	UNDERGROUND	TYPE	QTY	3	4" CLASS 250 SDR 15 PVC		
4	PAINTING			4	UNDERGROUND	TYPE	QTY	4	4" CLASS 250 SDR 15 PVC		
5				5	UNDERGROUND	TYPE	QTY	5	4" CLASS 250 SDR 15 PVC		
6				6	UNDERGROUND	TYPE	QTY	6	4" CLASS 250 SDR 15 PVC		
7				7	UNDERGROUND	TYPE	QTY	7	4" CLASS 250 SDR 15 PVC		
8				8	UNDERGROUND	TYPE	QTY	8	4" CLASS 250 SDR 15 PVC		
9				9	UNDERGROUND	TYPE	QTY	9	4" CLASS 250 SDR 15 PVC		
10				10	UNDERGROUND	TYPE	QTY	10	4" CLASS 250 SDR 15 PVC		
11				11	UNDERGROUND	TYPE	QTY	11	4" CLASS 250 SDR 15 PVC		
12				12	UNDERGROUND	TYPE	QTY	12	4" CLASS 250 SDR 15 PVC		

GENERAL NOTES - SITE UTILITIES

1) ALL MATERIAL, EQUIPMENT, INSTALL, TESTING & APPROVALS AS PER CITY OF ADDISON & NFPA.

2) ALL PIPE TO BE PLACED ON 4" SAND BASE w/ 1'-0" SAND ABOVE PIPE. AFTER VISUAL INSPECTION & HYDRO TEST AS PER CITY, BACK FILL AS PER CITY, DEPTH OF BACKFILL NOT TO EXCEED 5 FT.

3) ALL PVC TO BE CLASS 250 SDR 15, ALL DUCTILE IRON TO BE D150.

4) ALL FITTINGS & LARGER TO BE N.S. 4 AND.