

**Embrey Builders, LLC**  
1020 N. E. Loop 410, Suite 700  
San Antonio, TX 78209  
Ph: (210) 824-6044 Fax: (210) 824-7656

**RFI**

**To:** Walter Kilroy  
BGO Architects  
4144 N. Central Expressway  
Suite 855  
Dallas, TX 75205  
Ph: (214)520-8878

**RFI #: 218**  
**Date:** 2/11/2013  
**Job:** EB-02 Keller Springs Lofts  
**Phone:** 877-777-5115

**CC:**

**Subject:** Door Mark #30 in A4 Alt F unit # 1167

**Drawing:** 2.0A, 2.5, 3.1F, 4.5  
**Cost Impact:** None

**Spec Section:**  
**Schedule Impact:** None

**Request:** **Date Required:** 2/15/2013  
In section #7 unit #1167 which is the only A4 Alt F unit on the project, the plans show a door mark #30 which on sheet 2.0A shows it being a pair of 3'-8" storefront. There has been discussion on changing this to a typical unit exterior French door which would be a pair of 3'-6" with one operable right hand door with the other being a fixed light panel. By doing this, the door would match the appearance of adjoining, and all other exterior French doors.

**Requested by:** Bryan Pickler  
Embrey Partners, Ltd.

**Response:**  
Yes please provide a French door to match other balcony doors.

**Answered by:** Walter Kilroy  
BGO Architects

**Answered date:** February 12, 2013