

EMBREY BUILDERS, LLC.

1020 N. E. Loop 410, Suite 700
San Antonio, TX 78209
Ph : (210) 824-6044 Fax: (210) 824-7656

RFI

To: Erik Eamshaw
BGO Architects
4144 N. Central Expressway
Suite 855
Dallas, TX 75205
Ph: (214)520-8878

RFI #: 44
Date: 1/27/2012
Job: EB-02 Keller Springs Lofts
Phone: 877-777-5115

CC: David Gallagher (Embrey Builders LLC)

Subject: Conflict with floor plan on A1 all A unit

Drawing: 7/2.2 Spec Section:
Cost Impact: None Schedule Impact: None

Request: Date Required: 2/2/2012
7/2.2 shows A1 all A unit. It shows (3) H marked windows. (2) in the living room and (1) in the bedroom. On the window schedule on sheet 2.0 an H window is a single hung 3' 6" window. On 7/2.2 the bedroom H window is larger (4'). Please advise.

Requested by: Bryan Pickler
Embrey Partners, Ltd.

Response:
The window in question is an "H" as accurately keyed and shown in elevation.
Please see next page for the floor plan update.

Ryan Faulds
Answered by: BGO architects Date: Feb 24, 2012
Company: Date: