

EMBREY BUILDERS, LLC.
 1020 N. E. Loop 410, Suite 700
 San Antonio, TX 78209
 Ph: (210) 824-6044 Fax: (210) 824-7656

RFI

To: Erik Earnshaw
 BGO Architects
 4144 N. Central Expressway
 Suite 855
 Dallas, TX 75205
 Ph: (214) 920-8878

RFI #: 21
 Date: 1/3/2012
 Job: EB-02 Keller Springs Lofts
 Phone: 877-777-5115

CC: Trent Perkins (Parkin Perkins Olsen)
 Subject: Elevation eastside of garage

Drawing: 3.1D
 Cost Impact: None
 Spec Section:
 Schedule Impact: None

Request: Sheet 3.1D shows elevation 641'-1 1/4" at the corridor of the building on the eastside of garage near A4 at G. unit and ramp. Shouldn't the elevation be 641'-7 1/4" ?
 Date Required: 1/10/2012

Requested by: Bryan Pickler
 Embrey Partners, Ltd.

Response:
 Correct 641'-7 1/4" as this part of the corridor on sheet 3.1C

Erik Earnshaw
 Answered by BGO Architects
 Date: 01-05-2012

Embrey Builders, LLC
 1020 N. E. Loop 410, Suite 700
 San Antonio, TX 78209
 Ph: (210) 824-6044 Fax: (210) 824-7656

RFI

To: Ryan Faulds
 B.G.O. Architects, Inc.
 4245 N. Central Expressway
 Dallas, TX 75205
 Ph: (210) 829-1898 Fax: (210) 829-1899

RFI #: 197
 Date: 10/12/2012
 Job: EB-02 Keller Springs Lofts
 Phone: 877-777-5115

CC: Walter Kilroy (BGO)
 Subject: Required spacing measurement between top of CMU wall and bottom of double T flange

Drawing: SK-15
 Cost Impact: None
 Spec Section:
 Schedule Impact: None

Request: Please provide the required spacing measurement between the top of the cmu wall and the bottom of the double T flange. The camber of the double T across the width of the garage should be considered in this gap measurement, along with the potential deflection from vehicle traffic on the precast drive surface. Also, we will need the detail/spec for sealing the top of the cmu to the bottom of the double T flange.
 Date Required: 10/19/2012

Requested by: Bryan Pickler
 Embrey Partners, Ltd.

Response: This RFI was answered with architectural SK-15.

Ryan Faulds
 BGO architects
 October 16, 2012

Answered by
 Company
 Date

RFI 197 SK-15A

