

EMBREY BUILDERS, LLC.

1020 N. E. Loop 410, Suite 700
San Antonio, TX 78209
Ph : (210) 824-6044 Fax: (210) 824-7656

RFI

To: Enviro Design Landscape
7424 Greenville Ave, Suite 200
Dallas, TX 75231
Ph: 214/987-3010 Fax: 214/987-3015

RFI #: 7
Date: 12/1/2011
Job: EB-02 Keller Springs Lofts
Phone: 877-777-5115

CC: David Gallagher (Embrey Build (Embrey Construction LLC))

Subject: RFI# 7 pool fence height

Drawing: None **Spec Section:** None
Cost Impact: None **Schedule Impact:** None

Request: For clarification what is the pool fence height? **Date Required:** 12/8/2011

Requested by: Bryan Pickler
Embrey Partners, Ltd.

Response: Per Detail H/6C pool fence height is 4' 3"

Answered by: Enviro Design Landscape **Answered date:** December 05, 2011

Page 1 of 1

Embrey Builders, LLC

1020 N. E. Loop 410, Suite 700
San Antonio, TX 78209
Ph : (210) 824-6044 Fax: (210) 824-7656

RFI

To: Enviro Design Landscape
7424 Greenville Ave, Suite 200
Dallas, TX 75231
Ph: 214/987-3010 Fax: 214/987-3015

RFI #: 216
Date: 12/18/2012
Job: EB-02 Keller Springs Lofts
Phone: 877-777-5115

CC:

Subject: 12" paver bands in courtyards

Drawing: 4C & 5C **Spec Section:** None
Cost Impact: None **Schedule Impact:** None

Request: THE POOL SUBCONTRACTOR NEEDS TO KNOW IF THE 12" BANDS ARE SINGLE PAVERS 12" X 12" OR ARE THE 4" X 8" IN 12" PATTERNS PLEASE ADVISE. **Date Required:** 12/19/2012

Requested by: Bryan Pickler
Embrey Partners, Ltd.

Response: the 12" paver bands in the courtyards are city stone III (12x12) single pavers in a stacked bond layout.

Answered by: Enviro Design Landscape **Answered date:** December 18, 2012

Page 1 of 1