
DATE

19 AUG 2011

SHEET

TITLE IF WATER FEATURE(6) ARE DETERMINED TO FALL UNDER CONSTRUCTION

(ASME/ANSI A112.19.8a-2008).



- ALL ROOF DOWNSPOUTS DISCHARGING INTO COURTYARD AREAS SHALL BE TIED INTO THE
- UNDERGROUND STORM DRAIN SYSTEM (REF. CIVIL). REFER TO SHEET 3C FOR ACCESSORIES LIST

REFER TO SHEET 4C FOR CONSTRUCTION LEGEND

- CARD, OR COMBINATION LOCK ONLY: * INSTALL ON BOTH SIDES OF GATE WHEN GATE SHIELD IS NOT INSTALLED ·INSTALL ON OUTSIDE OF POOL FENCE WITH LATCH ON POOL SIDE ONLY WHEN GATE SHIELD IS INSTALLED.

POOL AND/OR SPA INSTALLATION AND EQUIPMENT SHALL BE COMPLIANT WITH THE VIRGINIA GRAEME-BAKER POOL AND SPA SAFETY ACT

• REFER TO DETAIL 6C.

ELECTRONIC DRAWING FILE IS RELEASE R THE AUTHORITY OF RICHARD B. ARTH

FLATWORK AND GRADE COORDINATE BUILDING GRADES AND ADD POOL

CONNECT DECK / AREA DRAINS TO STORM SEWER. REFERENCE CIVIL ENGINEER'S PLANS FOR LOCATION OF STORM SEWER DRAINS AND DRAINLINE TO BE SIZED BY CIVIL ENGINEER.

ALL WINDOWS OPENING DIRECTLY INTO THE POOL YARD SHALL HAVE A PERMANENT SAFETY GRILL MEETING ALL POOL ENCLOSURE REQUIREMENTS OR BE PERMANENTLY FIXED. REFERENCE ARCH. DRAWINGS.

ALL PATIO ENCLOSURES AND/OR RAILINGS DIRECTLY ADJACENT TO THE POOL YARD SHALL MEET ALL POOL ENCLOSURE REQUIREMENTS.

POOL CLASSIFICATION: CLASS C

'911' EMERGENCY TELEPHONE:

REQUIRED.

(1) WALL MOUNT WITH APPROPRIATE SIGNAGE. YERIFY LOCATION AND PROVIDE UTILITIES AS

MAXIMUM NUMBER OF USERS IN POOL AT ANY TIME (15 SQ. FT. OF WATER SURFACE AREA PER USER)

| POOL - 2,825 SQ. FT. / 15 = 189 USERS

POOL DECK LIGHTING:

MINIMUM WATTAGE PER SQ. FT - 0.5 WATTS POOL DECK - 6,775 SQ. FT. x O.5 WATTS = 3,388 WATTS MINIMUM REQUIRED FOR ALL POOL DECK LIGHTING

MINIMUM WATTAGE PER SQ. FT - 0.5 WATTS POOL SURFACE - 2,825 SQ. FT. \times 0.5 WATTS = 1,413 WATTS MINIMUM REQUIRED FOR ALL POOL SURFACE LIGHTING

"TITLE 25 HEALTH SERVICES PART 1, CHAPTER 265 GENERAL SANITATION, SUBCHAPTER M PUBLIC INTERACTIVE WATER FEATURES AND FOUNTAINS", SECTION 265.301-265.308 OF THE TEXAS ADMINISTRATIVE CODE, THE POOL CONTRACTOR AND/OR INSTALLER SHALL MEET ALL APPLICABLE REQUIREMENTS.

5C OF 9