

EMBREY BUILDERS, LLC.
1020 N. E. Loop 410, Suite 700
San Antonio, TX 78209
Ph: (210) 824-6044 Fax: (210) 824-7656

RFI

To: Jordan & Skala Engineers, Inc. RFI #: 65
14240 Midway Road, Suite 350 Date: 2/23/2012
Dallas, TX 75244 Job: EB-02 Keller Springs Lofts
Ph: 469/385-1616 Fax: 469/385-1615 Phone: 877-777-5115

CC: Erik Earnshaw (BGO)

Subject: revised scale to coordinate with Architectural and Plumbing sheets

Drawing: 4/6.4, 3.1D, P-3.1D, P-9.1 Spec Section:
Cost Impact: None Schedule Impact: None

Request: Architectural 4/6.4 show inside dimensions for the Pump Room as 24'-6" X 17'-10", sheet 3.1D and P3.1D scale out the same using the 1/8" scale. Going to P-9.1 (which my plumber did) and using the 1/4" scale that is called out, the room scales to 21'-0" X 15'-6". The detail and sheet needs to be revised to scale to the correct dimensions which are 24'-6" X 17'-10" this error has already created problems with my plumber who had to move his plumbing underground after using the detail on P-9.1. **Date Required:** 3/1/2012

Requested by: Bryan Pickler
Embrey Partners, Ltd.

Response:
See attached sheet P-9.1 for corrected plan scale.

Russell Cox

Answered by: Jordan & Skala 3-01-2012
Company: Date

RECEIVED
MARCH 1 2012
KELLER SPRINGS LOFTS