

EMBREY BUILDERS, LLC.
1020 N. E. Loop 410, Suite 700
San Antonio, TX 78209
Ph: (210) 824-6044 Fax: (210) 824-7686

RFI

To: Trent Perkins
Parkin Perkins Olsen
9330 LBJ Freeway, Suite 1055
Dallas, TX 75243
Ph: (214)221-2220 Fax: (214)221-2252

RFI #: 112
Date: 5/4/2012
Job: EB-02 Keller Springs Lofts
Phone: 877-777-5115

CC:

Subject: Moving Piers at Stair Tower #5

Drawing: S2.14P
Cost Impact: None

Spec Section:
Schedule Impact: None

Request: Date Required: 5/9/2012
Please confirm that we can move the P5 piers at the south end of Stair Tower 5 two feet to the north. This is to accommodate underground conduits already in place.
Requested by: David Miller
Embrey Builders LLC

Response:
Confirming conversation in the field, piers may be located as indicated above to avoid conflicts with underground conduits.
R. Trent Perkins, P.E. May 28, 2012
Parkin-Perkins-Olsen Consulting Engineering, Inc.

NOT USED

Answered by

Company Date