



PROVIDE 4'-2" X 6'-9" ID LEVEL OPENING FOR R.T.U. CURB LOCATION FIELD COORDINATED

PROVIDE 4'-2" X 6'-9" ID LEVEL OPENING FOR R.T.U. CURB LOCATION FIELD COORDINATED

PROVIDE 4'-2" X 6'-9" ID LEVEL OPENING FOR R.T.U. CURB LOCATION FIELD COORDINATED

PROVIDE 4'-2" X 6'-9" ID LEVEL OPENING FOR R.T.U. CURB LOCATION FIELD COORDINATED

- KEYNOTES:**
1. REMOVE 1" CONDENSATE DRAIN TO HUB DOWN BELOW ROOF. SEE PLUMBING PLANS FOR EXACT LOCATIONS.
 2. ALL OUTSIDE AIR INTAKES SHALL MAINTAIN 10'-0" FROM EXHAUST TERMINATIONS AND PLUMBING VENTS.
- NOTES:**
1. INSTALL CONDENSATE ON CHIM (BY OTHERS).
 2. THERE SHALL BE NO ROOF PENETRATIONS WITHIN 4'-0" OF A TERMINAL.
 3. COORDINATE REFRIGERANT LINES, HOODS AND LINES SET BEFORE CONSTRUCTION.
 4. ALL EQUIPMENT INSTALLED WITHIN 10'-0" OF A ROOF EDGE SHALL HAVE GUARDS TO COMPLY WITH 2009 IBC SECTION 30A.11.

KEYNO

- ① ROOF 1 PLAN F
- ② ALL OUT TERMINAL

NOTES:

- 1. INSTALL CC
- 2. TRIM END OF A PIPE
- 3. GROUNDING REQUIRED PER
- 4. ALL EQUIP EDGE SEAL SECTION 3C

AS BUILT

FOR APPROVAL ONLY

REV.	DATE	BY	DESCRIPTION

**KELLER SPRINGS
ROOF PLAN
EQUIPMENT LAYOUT**

TDI Industries
13850 Diplomat Drive
P.O. Box 819060
Dallas, Tx. 75381-9060
(972) 888-9300

JOB NO. DWG. NO.

B-11485-3-401 1 of 2