
# EXHAUST FAN DUCTING DETAIL

# TOP LEVEL EXHAUST FAN DUCTING DETAIL


#### INTERIOR PARTITION WALL HAVING ADEQUATE DEPTH FOR INSTALLATION OF VENT BOX TOP PLATE SHALL BE CUT AND FIRESTOPPED USING UL APPROVED FIRE DRYER VENT BOX, MODEL 4D STOP MATERIAL ----BY IN-O-VATE, UL RATED FOR 1-HR WALL, DETAIL W-L-7129 -----DRYER VENT BOX, MODEL 425 BY IN-O-VATE, UL RATED FOR 1-HR WALL, DETAIL W-L-7129 ---- FINISHED FLOOR INTERIOR PARTITION WALL 4"ø OR 5"ø EXHAUST VENT DOWN THRU FLOOR PLATE AND INTO CUT AND FIRESTOPPED TRUSS SYSTEM, TRANSITION IN USING UL APPROVED FIRE TRUSS SYSTEM FROM A 4"ø TO

### TOP LEVEL DRYER VENT DUCTING DETAIL




1. DRYER VENT BOXES IN FIRE RATED WALLS SHALL BE UL LISTED. 2. INSTALL MANUFACTURED ONE HOUR RATED "DRYER BOX" BY IN-O-VATE. 3. INSTALL PER MANUFACTURER'S REQUIREMENTS TO MAINTAIN FIRE RATING. WWW.DRYERBOX.COM

DRYER VENT BOX DETAIL SCHEMATIC - NO SCALE



LOWER LEVELS DRYER VENT DUCTING DETAIL



1. PROVIDE WITH INTEGRAL BACKDRAFT DAMPER
2. WALL CAP BY VENTCRAFT, OR APPROVED EQUAL. 3. PROVIDE CAP WITH PAINT GRIP COATING FOR FIELD PAINTING.

DRYER AND TOILET EXHAUST WALL CAP DETAIL

#### DX PACKAGED ROOFTOP UNITS WITH GAS HEAT

TAG	MODEL No.	NOMINAL TONS	COOL/HEAT DUTY	TOTAL CFM	MIN. O.A. CFM	ESP (IN.WG)	MAX FAN BHP	COOLING		HEATING		100500005	
								MBH COOL. TOTAL	MBH COOL. SENSIBLE	EER	INPUT	OUTPUT	ACCESSORIES
RTU-1,2,3,4,5 6,7,8	48HCEB07	6.0	COOL/HEAT	2,400	615	1.0	1.96	70.8	53.0	12.0	90.0/125.0	103.0	1,2,3,4,5,6,7,8,9,10,11,12,13,14,15,16,17,18

9. FACTORY-INSTALLED HUMIDIMIZER DEHUMIDIFICATION SYSTEM.

15. REMOTE THERMOSTAT SENSOR FOR DRY BULD AVERAGING AT

10. FIELD SUPPLIED BELT DRIVE.

13. BAROMETRIC RELIEF DAMPER.

14. ECONOMIZER.

SEE CALCS. BELOW

SEE CALCS BELOW

FOR DESIGN

LENGTH

INFORMATION

4" VERTICAL RISER / 5" HORIZONTAL

CODE PRESSURE LOSS => 25 FT. x 2.2 IN. W.G. / 100 FT. = 0.55 IN. W.G.

(TO BE USED WHEN 2009 IMC SECTION 506.4.1 CANNOT BE MET)

(1) CALCULATE ALLOWABLE DUCT PRESSURE LOSS PER 2009 IMC 506.4.1:

(2) ALTERNATE ENGINEERED DESIGN IS COMPOSED AS ILLUSTRATED ABOVE:

VERTICAL LENGTH 1: 6'-0" OF 4" VERTICAL DUCT = 0.13 IN. W.G.

(4) CALCULATE THE MAXIMUM EQUIVALENT 5" ROUND HORIZONTAL DUCT LENGTH LIMITATIONS:

MAXIMUM EQUIVALENT 5" HORIZ. DUCT LENGTH = MAX. 5" PRESS. LOSS / f5 =>

3. ONE (1) 4"-TO-5" ROUND TRANSITION INCREASER.

(3) FITTING PRESSURE LOSS DEDUCTIONS AND FRICTION FACTORS:

1: 0.55 IN. - 0.13 IN. - 0.11 IN. = 0.31 IN. W.G.

1: 0.31 IN. / (0.76 IN./100 FT.) = 40.8 EQUIVALENT FT.

ALTERNATE DRYER VENTING SUBJECT TO BUILDING OFFICIAL APPROVAL

- DRYER VENT BOX

COEFFICIENT OF FRICTION (f4) FOR 200 CFM THROUGH 4" ROUND DUCT = 2.2 IN. W.G. PER 100 FT.

1. A VERTICAL LENGTH OF 4" ROUND VENT DUCT STUBBED UP FROM A RECESSED DRYER VENT BOX.

COEFFICIENT OF FRICTION (15) FOR 200 CFM THROUGH 5" ROUND DUCT = 0.76 IN. W.G. PER 100 FT.

MAXIMUM 5" HORIZ. DUCT PRESS. LOSS = CODE PRESS. LOSS - 4" VERTICAL DUCT LOSS - 4" ELBOW =>

THEREFORE THE MAXIMUM ALLOWABLE PRESSURE DROP THROUGH THE 5" ROUND DUCT IS 0.31 IN. W.G.

THEREFORE THE MAXIMUM EQUIVALENT 5" ROUND HORIZONTAL DUCT LENGTH IS

40.8 EQUIVALENT FT. AND THE TOTAL EQUIVALENT LENGTH IS 51.8 EQUIVALENT FT.

CODE ALTERNATE DRYER VENT

LENGTH DESIGN WITH VENT BOX

2. ONE (1) 4" ROUND 90' ELBOW AT THE TOP OF THE VERTICAL DUCT WITHIN THE RATED FLOOR/CEILING ASSEMBLY.

4. A HORIZONTAL LENGTH OF 5" ROUND VENT DUCT ROUTED OUT THROUGH THE EXTERIOR WALL TO A WALL CAP.

THEREFORE ALTERNATE ENGINEERED DESIGN MUST NOT EXCEED 0.55 IN. W.G. PRESSURE LOSS THROUGH THE DRYER VENT SYSTEM.

FOR ALLOWABLE LENGTHS — |-

--- 5"ø HORIZONTAL VENT

WALL CAP

11. SMOKE DETECTOR IN RETURN AIR DUCT.

12. SUPPLY AIR FANS SHALL RUN CONTINUOUSLY.

LOWEST AND HIGHEST FLOORS SERVED.

47. MOJORIZED O TOOK OUTSIDE AIR BAMPET

18. POWERED EXHAUST. (RTU-1,3,5,7) ONLY

16. MINIMUM OF 2 STAGES OF GAS HEAT.

A. COOLING CAPACITY BASED ON 80°F DB/67°F WB ENTERING AIR TEMPERATURE AND 105°F DB OUTDOOR AIR TEMPERATURE. B. R-410a REFRIGERANT.

ACCESSORIES:

HORIZONTAL CONFIGURATION WITH 14" MIN HIIGH ROOF CURB. 2. 7-DAY PROGRAMMABLE COMBINATION THERMOSTAT/HUMIDISTAT WITH LOCKING

COVER BY UNIT MANUFACTURER. . COMPRESSOR ANTI-RECYCLE CONTROLS.

4"ø ELBOW-

4"ø VERTICAL VENT —

<u>DRYER</u>

TRANSITION DUCT BY TENANT —

BASIS FOR ALTERNATE DESIGN:

PER CODE - 25 FT. EQUIVALENT

4" 90 DEGREE ELBOW = 0.11" 4"-T0-5" INCREASER = 0.00" WALL CAP TERMINATION = 0.00"

TYPICAL DRYER EXHAUST RATE - 200 CFM

INCREASER-

4. UNIT SHALL SHUTDOWN UPON SIGNAL FROM BUILDING FIRE ALARM SYSTEM. PROVIDE SMOKE DETECTOR IN RETURN AIR DUCT. . BELT DRIVE MOTOR.

5. LOW AMBIENT OPERATION. . CRANKCASE HEATER.

8. SINGLE POINT POWER CONNECTION WITH DISCONNECT.

SELECTIONS ARE BASED ON PRODUCTS BY: CARRIER.

# GARAGE VENTILATION CONTROL SYSTEM

CARBON MONOXIDE DETECTION SYSTEM: PROVIDE (1) STAND ALONE GAS DETECTION SYSTEM WITH FIVE TO SIX REMOTE SENSORS PER PARKING GARAGE LEVEL MANUFACTURED BY CRITICAL ENVIRONMENT TECHNOLOGIES (RANDY BARNES AT BARTOS INDUSTRIES 214-350-6871). INCLUDED WITH THE CARBON MONOXIDE CONTROL SYSTEM WILL BE A WATER/DUST TIGHT CORROSION RESISTANT CONTROL PANEL ENCLOSURE AND AUTOMATIC RESETTING THERMAL CIRCUIT FUSE.

EVERY GAS DETECTION CONTROL PANEL AND REMOTE SENSOR SHALL BE INTERLOCKED TO THE FAN(S) AS NOTED ON THESE PLANS AND SCHEDULES. MECHANICAL VENTILATION SYSTEMS FOR ENCLOSED PARKING GARAGES ARE NOT REQUIRED TO OPERATE CONTINUOUSLY WHERE THE SYSTEM IS ARRANGED TO OPERATE AUTOMATICALLY UPON DETECTION OF A CONCENTRATION OF CARBON MONOXIDE OF 25 PARTS PER MILLION (PPM). THE SYSTEM SHALL NOT REDUCE THE VENTILATION RATE BELOW 0.05 CFM/SQFT OF FLOOR AREA AND SHALL BE CAPABLE OF PRODUCING A VENTILATION RATE OF 1.5 CFM/SQFT OF FLOOR AREA.

MODEL NUMBERS:

CO CONTROL PANEL: PDCA088 (LOCATE PANELS AS SHOWN ON PLANS)

REMOTE CO DETECTION SENSOR (TYP. 5): DST-MCO (LOCATE SENSORS AS SHOWN ON PLANS)

#### ELECTRIC HEATERS

TAG	MODEL No.	DESCRIPTION	HEAT CAPACITY	MOUNTING	ACCESSORIES
EH-A	AFA	WALL HEATER	4.0 kW	SEE DRAWINGS	1,2,3,4
 EH-B	AFA	WALL HEATER	3.0 kW	SEE DRAWINGS	1,2,3,4

A. UNIT INSTALLED MUST BE CAPABLE OF DELIVERING KW OUTPUT SPECIFIED AT AVAILABLE VOLTAGE AND PHASE.

**ACCESSORIES:** 

. TAMPER PROOF CONTROLS. 2. INTEGRAL THERMOSTAT & DISCONNECT SWITCH.

3. AUTO-RESET THERMAL OVERLOADS.

WALL/CEILING MOUNTING BRACKET.

SELECTIONS ARE BASED ON PRODUCTS BY: RAYWALL

#### DUCTLESS SPLIT SYSTEM HEAT PUMPS

	TAG	MODEL NO. OUTDOOR/INDOOR	AIRFLOW (INDOOR UNIT) (CFM)	TOTAL COOLING (MBH)	TOTAL HEATING (MBH)	COOLING EAT (DB/WB)	ACCESSORIES	
	AH\HP-E1,E2	PUZ-A18NHA/PKA-A18GAL	425	18.0	19.0	80/67	1,2,3,4,5,6	* *
	ALL HP-1	PUZ-A18NHA/PKA-A18GAL	425	18.0	19.0	80/67	1,2,3,4,5,6	
	AH\HP-M	PUZ-A18NHA/PKA-A18GAL	425	18.0	19.0	80/67	1,2,3,4,5,6	
1	AHHR-72	PUZ-A36NHA/PKA-A36GAL	990	34.2	37.0	80/67	1,2,3,4,5,6	
	AH\HP-FP	PUZ-A36NHA/PKA-A36GAL	990	34.2	37.0	80/67	1,2,3,4,5,6	

A. COOLING CAPACITIES BASED ON 95°F AMBIENT COOLING, 80°F db/67°F wb ENTERING AIR TEMPERATURE AND 47°F AMBIENT HEATING. B. ROUTE 3/4" AH CONDENSATE TO NEAREST PLUMBING DRAIN. SEE PLUMBING DRAWINGS.

#### ACCESSORIES:

MICROPROCESSOR CONTROL WITH NON-REMOVABLE MOUNTING BRACKET.

DISCONNECT SWITCH FOR INDOOR UNIT SHALL BE BY DIVISION 16. DISCONNECT SWITCH FOR OUTDOOR UNIT SHALL BE BY DIVISION 16 4. CONDENSATE PUMP W/CHECK VALVE ON INDOOR UNIT (FIELD MOUNTED)

5. WASHABLE FILTER. 6. PRE-CHARGED REFRIGERANT LINE SET.

C. 13 SEER MINIMUM UNITS.

SELECTIONS ARE BASED ON PRODUCTS BY: MITSUBISHI.

#### WALL LOUVERS

A. FINAL COLOR SELECTION SHALL BE MADE BY ARCHITECT AT TIME OF SHOP DRAWING APPROVAL.

ACCESSORIES:

1. BIRD SCREEN.

		and a second contract of the second							
TAG	MODEL No.	DUTY	SIZE WxH (INCHES)	FREE AREA (SQ.FT.)	CFM	MAX. PRESS. DROP (IN. W.C.)	OPERATOR	ACCESSORIES	
WL-A	EAH-690	RELIEF	72"x18"	3.0	SEE PLANS	0.05"	ELECTRIC	1,2,3,4	
WL-B	EDJ-401	EXHAUST	24"x12"	0.60	SEE PLANS	0.05"	NONE	1,2	
WL-C	EDJ-401	INTAKE	30x12"	0.75	SEE PLANS	0.05"	NONE	1,2	

2. BAKED ENAMEL FINISH.

3. SHALL BE NORMALLY CLOSED BUT SPEN DURING LOSS OF POWER AND DURING FIRE ALARM.
4. INTERLOCK TO FIRE ALARM SYSTEM / SMOKE DETECTOR.

SELECTIONS BASED ON GREENHECK!

Drawn By: CJH

HON PAN WONG 108985

REVISIONS

9-2-2011 2 9-13-2011 ANSI/FHA COMMENTS

3\9-23-2011

10-17-2011 CONSTRUCTION



4144 N. Central Expy.
Suite 855
Dallas, TX 75204
214.520.8878

bgoarchitects.com

08 - 05 - 1

PROJECT

SHEET NUMBER

DETAILS & SCHEDULES MECHANICAL

dan & Skala Engineers

240 Midway Road, Suite 350 Dallas, TX 75244-5138 (469) 385-1616 F: (469) 385-1615 Texas Firm Registration # F-499 Checked By: AHS