



- GENERAL NOTE:**
1. CONCRETE - NORMAL WEIGHT, 3000 PSI. @ 28 DAYS
  2. REINFORCEMENT - ASTM A 618 - GR. 60
  3. MASONRY - COMPRESSIVE STRENGTH OF 3000 PSI,  $f'_m = 900$  PSI
  4. WIND LOAD - 30 PSF
  5. PIER BEARING STRESS - SEE BRICK SCREENING WALL NOTES
  6. MORTAR - TYPE S, 1800 PSI
  7. POSITIVE CENTER JOINTS @ 10 FT
  8. POSITIVE CENTER JOINTS @ 200 FT ON CENTER MAXIMUM
  9. WHERE THERE IS AN ALLEY PAVEMENT, PROVIDE MIN. 9 FT. LENGTH OF PIERS. THIS APPLIED TO BOTH THE REINFORCED CONCRETE SCREENING WALL AND THE BRICK SCREENING WALL
  10. ALL EXPOSED CONCRETE SHALL HAVE FINISHED SURFACE.

PAY ITEM 432.1

NO.	REVISION	BY	DATE

TOWN OF ADDISON, TEXAS  
DEPARTMENT OF ENGINEERING  
STANDARD CONSTRUCTION DETAILS  
PAVING  
SCREENING WALL - SIDEWALK

APPROVED: H WAYNE GINN, PE  
DATE MARCH, 1984



**BRICK SCREENING WALL**