

LEGEND:

- ROADWAY LIGHTING LUMINAIRE 400 WATT HIGH PRESSURE SODIUM, TYPE III DISTRIBUTION.
- ROADWAY LIGHTING LUMINAIRE 400 WATT HIGH PRESSURE SODIUM, TYPE II DISTRIBUTION.
- HO WALL-MOUNTED LIGHTING FIXTURE 150 WATT HIGH PRESSURE SODIUM.
- () W. P. TOGGLE SWITCH.
- PHOTOCELL
- ——

 ☑ GROUND—MOUNTED LIGHTING UNIT.
- ----O STRUCTURE-MOUNTED LIGHTING UNIT.
- GROUND-MOUNTED ROADSIDE SIGN WITH LIGHTS, AS NOTED ON THE PLAN.
- GROUND-MOUNTED OVERHEAD SIGN WITH LIGHTS, AS NOTED ON THE PLAN.
- NEW GROUND PULL BOX, SEE SHEET NO. 9.
- PREVIOUSLY INSTALLED GROUND PULL BOX.
- PREVIOUSLY INSTALLED EMBEDDED STRUCTURE PULL BOX.
- ----- PREVIOUSLY INSTALLED CONDUIT.
 - DUCT-CABLE WITH INSULATED AND ONE BARE CONDUCTOR, SIZE AS SHOWN ON THE PLAN.
 - NEW UNDERGROUND CONDUIT, SIZE AS SHOWN ON THE PLAN.
 - CONDUIT AND CONDUCTOR RUNS NUMBER, REFER
 TO SHEET NO. 4, QUANTITY/ITEMS SUMMARIES.

GENERAL NOTES

1. COORDINATE DUCT-CABLE AND CONDUIT INSTALLATION WITH CIVIL CONSTRUCTION ELEMENTS-UNDERDRAINS, CONCRETE GUTTERS, FENCES, ETC.

THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY RICHARD J. MILLER, P.E. NO. 42812 ON JANUARY 12, 1999. ALTERATION OF A SEALED DOCUMENT WITHOUT PRIOR NOTIFICATION TO THE RESPONSIBLE ENGINEER IS AN OFFENSE UNDER THE TEXAS ENGINEERING PRACTICE ACT.

FINAL RECORD DRAWING Date: 12/25/99




A REVISED PER REI # 198

NORTH TEXAS TOLLWAY AUTHORITY

ADDISON AIRPORT TUNNEL

ROADWAY ILLUMINATION LAYOUT STA. 0+00 TO STA. 3+50



F:\96112\PLANS\LIGHTING\C1.DGN