

SITE PLAN

Scale: 1" = 20'

Tower Flow @

$T = \frac{5238 \times 42}{100} = 2220.9$

$A\ \frac{T}{SK\ (0.60)} = \frac{2220.9}{5K\ (0.60)} = .60\ ft^2$

Height = 60'+

Width = 1.60'+

Flow Test Data: Year = 96

Static = 72

Residual = 42

Flow = 2220

GENERAL NOTES

1. System to be designed and installed in accordance with NFPA 13.
2. All material and equipment installed in system shall be U.L. listed.
3. All threaded fittings are to be cast iron-cast 125.
4. All piping 2 1/2" & larger shall be schedule 10 (unless noted otherwise), joined with roll groove and groove fittings.
5. All piping 2" and smaller shall be schedule 40.
6. All piping is black steel and meets specifications set forth by ASTM as required by NFPA 13, Table 3-1.1.1.
7. All hangers and components shall be ferrous.
8. All hangers and components shall be U.L. listed and shall conform to all requirements set forth by NFPA 13, section 3-10.
9. All electrical installations are to be performed by others.
10. See title block for system design data, flow test data and occupation classification.

RECORD OF WORK
AS-BUILT

GOLDEN TRIANGLE
FIRE PROTECTION, INC.
SCR #0273
ERWIN E. WISDOM
NME # 0420

WALL THICKNESS OF THIN WALL PIPE	REVIEWING AGENCY	SYSTEM		GENERAL NOTES
1" thru 2" = .109		WET ☑		
2½" thru 4" = .120		DRY ☐		CONTROL ELEVATION
5" and 6" = .134	OWNER OCCUPANT	DELUGE ☐	BTOS	BELOW TOP OF STEEL
8" and 10" = .165	THE HOH COMPANY	PREACTION ☐	AFF	ABOVE FINISHED FLOOR
	5235 Dooley Ave	FOAM ☐		CONTROL DIMENSIONS
	DALLAS TX 75225	COMBINATION ☐		SPRINKLER PIPING DIMENSIONS SHOWN ARE TO
		☐		
		☐		

STANDARD SYMBOLS	DESIGN CRITERIA	SPRINKLER HEADS					
	OCCUPANCY:	SYMBOL	TYPE	ORI	K	TEMP.	QUAN
UPRIGHT	HAZARD:						
	CLASS:						
PENDANT	DENSITY:						
UPRIGHT OR 1" SPRIG UP	CALCULATED AREA:						
	AREA PER SPRINKLER:						
PENDANT OR 1" DROP	STORAGE HEIGHT:						
	NOTES:		TOTAL HEADS THIS SHEET				
SPRINKLER GUARD			TOTAL HEADS FOR PROJECT				
SIDEWALL SPRINKLERS	GOLDEN TRIANGLE FIRE PROTECTION, INC. P.O. Box 10630 Denton, Texas 76206 Metro 294-454-0990	PROJECT: EAGLE TRANSMISSIONS 16230 MIDWAY RD ADDISON TEXAS					
VALVE CONTROL		JOB NO:	DESIGNER			SYS. NO. 1	
FLOW CHECK VALVE		DATE: 6-12-97				SHEET NUMBER	
WATER CHECK VALVE		SCALE: NO	SJN			1 of 2	
SPRINKLER RISER							



8-8-1

FIRE SERVICE
16230 MIDWAY
EAGLE TRANSMISSION