



LOCATION MAP

GENERAL NOTES

- All water mains shall be ductile Iron Class 51 water pipe with polyethylene wrap on pipe, fittings, and fire hydrant bases.
- Alternate - All 6", 8", and 12" water mains shall be PVC Class 200 water pipe. For PVC service taps 1" and larger, tapping saddles shall be used.
- Water and sanitary sewer easements shall also include additional area for working space for construction and maintenance of the system. Additional easement area is also conveyed for installation and maintenance of manholes, cleanouts, fire hydrants, water serviced from the main to and including the meter boxes, sewer laterals from the main to the curb on pavement line and descriptions of such additional easements herein granted shall be determined by their locations as installed.
- Construction shall be in accordance with NCTCOG standard specifications for Public Works construction.
- All sanitary sewer laterals shall be located as shown, sized and referenced as follows: "a", "b", "c" = 2"
- All water deadheads shall be copper and located as shown, sized and referenced as follows: "a", "b", "c" = 2"
- Existing fire hydrants to be removed shall be delivered to Dallas Water Utilities Yard #2, 2901 Municipal.

△ LINE "A" ADJUSTED TO FIELD CONDITION, MOVED 6" WATER MAIN & DETECTOR CHECK

DESIGNED BY *[Signature]* DATE: 1-29-85
 R.O.W. APPROVED _____ DATE _____
 ENGINEER OF DESIGN WATER UTIL. DEPT. DATE: 1-30-85
 CONTRACT NO. _____

DESIGNED BY *[Signature]* DATE: 11-27-84
 R.O.W. APPROVED _____ DATE: _____
 ENGINEER OF DESIGN WATER UTIL. DEPT. DATE: 1-11-85
 CONTRACT NO. 84-835P 84-836P Triple H Const. 11-28-84

WATER & SEWER PLAN
 PRESTONWOOD POND 2
 TREECE & COMPANY, INC.
 WATER UTILITIES DEPT.
 CITY OF DALLAS, TEXAS

DESIGN	DRAWN	DATE	SCALE	NOTES	FILE	NO.
T. A. C.	T. A. C.	Oct. '84	1" = 40'		411Q	196C