



POINT OF ADJUSTMENT
 This set of plans contains various conditions and comments made by the City Staff. All installers will be required to comply with these conditions and comments before the start of work. If any conditions or comments are not in accordance with the approved construction which is in violation of local ordinances, this set of plans is to be kept on the job site at all times and is to be made available for use by city inspectors at their request. Failure to have these plans available may delay approval of a requested disposition.

- NOTES:**
- ① ALL RECEPTACLES IN THIS ROOM SHALL BE MOUNTED 54" A.F.F.
 - ② LOCATE ON ROOF JOIST.
 - ③ REMOVE ALL CONVENIENCE AND TELEPHONE OUTLETS IN THIS AREA UNLESS NOTED TO REMAIN. FIELD VERIFY EXISTING CONDITIONS.
 - ④ EXISTING TO REMAIN.
 - ⑤ TO NEXT AVAILABLE 20A, 1P CIRCUIT BREAKER IN EXISTING 120/240V, 1Ø, 3Ø PANEL. - SEE NOTE 9
 - ⑥ 3 #10, 3/4" C. TO EXISTING 30A, 2P CIRCUIT BREAKER IN EXISTING 120/240V, 1Ø, 3Ø PANEL. - SEE NOTE 9
 - ⑦ CONNECT TO EXISTING CIRCUIT AT EXISTING DEVICE SHOWN.
 - ⑧ EXISTING FIRE ALARM CONTROL PANEL TO REMAIN.
 - ⑨ EXISTING 120/240V, 1Ø, 3Ø PANEL TO REMAIN FOR POWER IN RE-MODELED OFFICE SPACE.
 - ⑩ ALL RECEPTACLES IN THIS ROOM SHALL BE MOUNTED 44" A.F.F.
 - ⑪ ALL RECEPTACLES IN THIS ROOM SHALL BE MOUNTED 34" A.F.F.
 - ⑫ EXISTING 240V, 3 Ø, 200A M.L.O. PANEL TO REMAIN.
 - ⑬ EXISTING 120/240V, 1Ø 3Ø 200A M.L.O. PANEL TO REMAIN.
 - ⑭ EXISTING 120/240V, 1Ø, 3Ø M.L.O. PANEL BELOW 3Ø PANEL TO REMAIN.
 - ⑮ EXISTING 120/240V, 3Ø, 4W 800A M.L.O. PANEL AND SERVICE TO BE REMOVED.
 - ⑯ TO EXISTING PANEL (SEE NOTE 13) PROVIDE NEW 20A, 1P CIRCUIT BREAKER.
 - ⑰ 3 #10, 1/2" C. TO EXISTING PANEL (SEE NOTE 13) PROVIDE NEW 30A, 2P CIRCUIT BREAKER.
 - ⑱ RELOCATED AIR COMPRESSOR.
 - ⑲ AIR COMPRESSOR TO BE RELOCATED.

01 FIRST FLOOR PLAN - POWER
 E2.1 1/8" = 1'-0"



EDI ARCHITECTS, INC.
 ARCHITECTURE PLANNING ENGINEERING
 8440 WALNUT HILL LANE
 SUITE 100
 GALLATON, TEXAS 75851
 817 / 950-8208

TOWN OF ADDISON

ADDITION TO PUBLIC WORKS SERVICE CENTER
 Westgrove Road
 Addison Texas

DATE:
 11 JUNE 86
 24 JULY 1986 - BID

SHEET NO:
E2.1
 OF SHEETS