



INSTALL 42 L.F. STEEL PIPE ENCASMENT
INSTALL 60 L.F. 8" P.V.C. WATER PIPE
SCALE: 1" = 20' - H
1" = 4' - V

- NOTES:
- 8" waterline shall be C-900 PVC DR-18.
 - Water main to have minimum depth of cover of 4' below existing grade or as required to clear other utilities. Embedment per city specs.
 - F.H. as required by city.
 - 6" sanitary sewer shall be D-3034 PVC DR-35.
 - Steel encasement pipe shall be smooth bore steel pipe, 14" O.D., 1/4" wall thickness, with bituminous coating.
 - Gate valves shall conform to the AWWA standard for gate valves for ordinary waterworks service, AWWA C 500.
 - Gate valves to be installed with valve box covers and extensions as required.
 - Contractor is cautioned that there may be existing utilities and services existing and not shown on the plan, verify location of all utilities.
 - All construction shall conform to City of Addison standards and specifications.
 - Block all fittings with 2000 p.s.i. conc. per city specs.

No.	Date	Revisions	EXIST. F.H.	L.H.E.	App.
1	AUG 86	RELOCATE EXIST. F.H.			

PAWA-Winkelmann & Associates, Inc.
CIVIL / TRANSPORTATION ENGINEERS / PLANNERS / SURVEYORS
12860 COIT ROAD, SUITE 200
DALLAS, TX 75251

TRINITY CHRISTIAN ACADEMY
ADDISON, TEXAS
CLIENT: TOM DANCE ARCHITECT
8950 N. CENTRAL EXPRESSWAY
DALLAS, TEXAS 75231

WATER & SANITARY SEWER PLAN

Scale: 1"=40'
Date: JUNE 1986
Designed by: N.B.A.
Drawn by: P.A.W.A.
Checked by:
Approved by:
4501 Sojourndr
Trinity Christian Academy

SHEET OF

B13-7