



- GENERAL NOTES:**
- ALL CONDUIT SHALL CONTAIN A HOT LEG, NEUTRAL AND GROUND LEG UNLESS INDICATED OTHERWISE.
 - SECURITY SYSTEMS:**
 THE CONTRACTOR WILL PURCHASE, INSTALL, PROGRAM, MAINTAIN AND TEST A TURN-KEY SECURITY SYSTEM. THE CONTRACTOR WILL PROVIDE AUTHORIZED INSTALLERS TO INSTALL, PROGRAM, MAINTAIN AND TEST THE SYSTEM. ALL EQUIPMENT AND SECURITY DEVICES ARE TO BE INSTALLED ACCORDING TO MANUFACTURER'S SPECIFICATIONS. ALL CONDUIT SIZING AND WIRING REQUIREMENTS ARE THE RESPONSIBILITY OF THE CONTRACTOR OR LESSOR. THE OWNER MUST APPROVE THE SECURITY SYSTEM DESIGN.
 THE SYSTEM SHALL INCLUDE THE FOLLOWING:
 (1) ONE CAMERA MOUNTED AT EVERY ENTRY/EXIT DOOR (5 TOTAL)
 (2) ONE CAMERA MOUNTED IN EACH CORNER OF OPEN OFFICE 106
 (3) EACH CAMERA SHALL HAVE AN INDIVIDUAL IP ADDRESS FOR OFF-SITE MONITORING.
 - MC CABLE WILL BE ACCEPTABLE IN LIEU OF EMT CONDUIT WHERE ALLOWED BY CODE.
 - SYMBOL ■ INDICATES A WIREMOLD #25DTP-4D TELE/DATA POLE W/ ALUMINUM FINISH.

FIRE ALARM SYSTEM
 THE BUILDING IS FULLY SPRINKLED. THE CONTRACTOR SHALL FURNISH AND INSTALL A FIRE SPRINKLER MONITORING SYSTEM W/ CONNECTIONS TO THE FIRE SPRINKLER FLOW AND TAMPER SWITCHES. PROVIDE PROVISIONS FOR 'OFF SITE' MONITORING W/ AUTO DIAL MODULE, & DEDICATED PHONE LINE. PROVIDE A MANUAL PULL STATION, HORN STROBE UNIT, SMOKE DETECTOR, PROVIDE EXTERIOR (W/) HORN STROBE PER CODE. PROVIDE REMOTE ANNUNCIATION IN RECEPTION 100. PROVIDE ADDITIONAL COMPONENTS AND EQUIPMENT (INCLUDING BATTERY BACKUP) REQUIRED BY CODE. FURNISH AND INSTALL A FIRE SPRINKLER MONITORING SYSTEM AS REQUIRED BY CODE.

01 FLOOR PLAN - POWER
 SCALE: 1/8"=1'-0"
 PLAN NORTH TRUE NORTH

THE SEAL ON THIS DOCUMENT WAS AUTHORIZED BY Samuel G. Toub, P.E. 36988 REGISTERED PROFESSIONAL ENGINEER
 2009.02.09
 14:15:59 -06'00"

Project # 9980
S. Toub & Associates Inc.
 Consulting Engineers Mechanical / Electrical
 13541 Omega Road, Dallas, Texas 75244
 972.986-6629
 © COPYRIGHT 2008

JANI KING CALL CENTER
4393 SUNBELT DRIVE
 ADDISON, TEXAS

PROJECT NUMBER: 2008098
 DATE: FEBRUARY 9, 2009
 SHEET NUMBER: FLOOR PLAN POWER
 OWNER: E3.01