2-4"CONDUIT FOR FUTURE EXPANSION

NEW LOCATION FOR ELECT. TRANSFORMER BY TP&L

4"C WITH 4 #500 MCM

2" EMPTY CONDUIT FOR FUTURE TELEPHONE

2 NEW TENNIS COURTS

4 EXIST. TENNIS COURTS

2"C W/ 4-#3, 4-#4

2"C W/ 4-#3, 4-#4, 2-#8

2"C W/ 4-#4, 4-#6

2"C W/ 4-#4, 4-#6, 2-#8

1¼"C W/ 4-#6, 2-#8

4-#6

4-#8

3-#8

PANEL "M"

M-1

M-1, 2

M-2, 3

M-5

M-6

M-7

M-8

M-9

M-10

M-11

TPL

TPL 22, 24, 26

2-4"C EACH W/ 4-#500MCM (CONDUIT UNDERGROUND FROM TRANSFORMER TO PANEL "N").

PROPOSED PAVED AREA WIRING BENEATH MUST BE SLEEVED

N-8, 10, 12

N-1, 3, 5

EXIST. CONDUIT & WIRE

N-2, 4, 6

RUN WIRE IN EXIST. CONDUIT 2-4" SLEEVES

EXIST. PERMANENT BLEACHERS

PANEL "N"

N-7, 9, 11

EXIST. ELECT. TRANSFORMER TO BE RELOCATED TO N.W. CORNER OF TENNIS COURTS

EXIST. FOOTBALL FIELD TERMINATION RELOCATE TO PANEL "N"

PROPOSED PAVED AREA WIRING BENEATH MUST BE SLEEVED

N-13, 15, 17

CONNECTION JUNCTION TO PANEL "P"

3"C W/ 4-#500 MCM

PANEL "P"

FIELDHOUSE

CONDUIT SHALL BE RUN OUTSIDE FIELDS AS DIRECTED, COORD. WITH EXIST. SPRINKLER LAYOUT.

LOCATE LIGHT POLES AS PER SHT/NO. 1, SITE PLAN.

1¼"C W/ 4-#4, 2-#8

2-1¼" CONDUITS UNDER PARKING DRIVE

M-11 RUN M-11 IN CONDUIT UNDER ROAD.

2-#8

ELEMENTARY SCHOOL

ARTS & SCIENCE

ELECTRICAL SITE PLAN

SCALE: 1"=30'-0"

NORTH

TELEDYNE POSI NO481

DATE 11-26-86
REVISION

REGISTERED ARCHITECT STATE OF TEXAS

TOM F. DANCE & ASSOCIATES, INC.
ARCHITECTURE PLANNING
8950 N. CENTRAL EXP. DALLAS, TEXAS 75231 214-691-4404

RECREATIONAL IMPROVEMENTS FOR
TRINITY PARK
ADDISON TEXAS

SHEET NO. 5 OF 6