



2035 Central Circle, Suite 110
 McKinney, TX
 75069-8524
 p| 972.562.4677
 f| 972.542.4366
 kleinfelder.com

STRAIGHT DRILLED SHAFT REPORT

TO: Town of Addison
 16801 Westgrove Drive
 Addison, TX 75001-5190

PROJECT: Vitruvian Park and Misc Projs
 Addison, TX
 PROJECT NO.: 99526 - 5

Test Date: 8-14-10
 Technician: Wadel.

Report Date: 8/2/2010
 Report No:

| | | | | | |
|--|---------------|--------------|--|--|--|
| IDENTIFICATION MARK | G-1 | M-1 | | | |
| SHAFT DIAMETER PLAN/ACTUAL (in.) | 48" / 48" | 48" / 48" | | | |
| GROUND SURFACE ELEVATION TOP OF SHAFT ELEVATION ¹ | 546.83' | 546.83 | | | |
| DEPTH TO BEARING STRATUM (ft.) | 18.33' | 17.0' | | | |
| DESCRIPTION OF BEARING STRATUM | Gray Shale. → | | | | |
| PENETRATION INTO BEARING STRATUM PLAN/ACTUAL (ft.) | 15.77' | 17.3' | | | |
| TOTAL DRILLED SHAFT DEPTH | 34.1' | 34.3' | | | |
| STEEL CASING DIAMETER (IN.)/DEPTH (ft.) | 48" ID / 15' | 48" ID / 15' | | | |
| PLUMBNESS VARIATION | Good. | Good. | | | |
| TIME DRILLING STARTED | 8:10 | 12:15 | | | |
| TIME DRILLING COMPLETED | 9:50 | 1:25 | | | |
| REINFORCING STEEL CAGE LENGTH (ft.) | 35.2' | 35.2' | | | |
| HORIZONTAL REBAR QUANTITY / SIZE | #4 spiral → | | | | |
| VERTICAL REBAR QUANTITY / SIZE | 20 #9's → | | | | |
| DOWELS IN PLACE | Yes | Yes | | | |
| CONDITION OF SHAFT BOTTOM BEFORE CONCRETE PLACEMENT | Clean & DRY | | | | |
| PLACEMENT OF CONCRETE STARTED | 11:00 | 2:12 | | | |
| PLACEMENT OF CONCRETE COMPLETED | 11:20 | 2:35 | | | |

Remarks: ¹ - Top of shaft elevation obtained from construction drawings / contractor

Reports to:
 2- Client

KLEINFELDER