



2035 Central Circle, Suite 110
 McKinney, TX
 75069-8524
 p| 972.562.4677
 f| 972.542.4366
 kleinfelder.com

STRAIGHT DRILLED SHAFT REPORT

TO: Town of Addison
 16801 Westgrove Drive
 Addison, TX 75001-5190

PROJECT: Vitruvian Park and Misc Projs
 Addison, TX
 PROJECT NO.: 99526 - 5

Test Date: 8-21-10
 Technician: Wade G.

Report Date: 8/2/2010
 Report No:

IDENTIFICATION MARK	D-1				
SHAFT DIAMETER PLAN/ACTUAL (in.)	54/54				
GROUND SURFACE ELEVATION TOP OF SHAFT ELEVATION '	546.83'				
DEPTH TO BEARING STRATUM (ft.)	18.0'				
DESCRIPTION OF BEARING STRATUM	Gray Shale				
PENETRATION INTO BEARING STRATUM PLAN/ACTUAL (ft.)	28.2'				
TOTAL DRILLED SHAFT DEPTH	44.2'				
STEEL CASING DIAMETER (IN.)/DEPTH (ft.)	15.0'				
PLUMBNESS VARIATION	Good				
TIME DRILLING STARTED	4:00 PM 8-20				
TIME DRILLING COMPLETED	12:15 PM 8-21				
REINFORCING STEEL CAGE LENGTH (ft.)	45.3'				
HORIZONTAL REBAR QUANTITY / SIZE	#4 Spiral				
VERTICAL REBAR QUANTITY / SIZE	24 #9's				
DOWELS IN PLACE	Yes				
CONDITION OF SHAFT BOTTOM BEFORE CONCRETE PLACEMENT	Clean & Dry				
PLACEMENT OF CONCRETE STARTED	1:50				
PLACEMENT OF CONCRETE COMPLETED	2:15				

Remarks: 1 - Top of shaft elevation obtained from construction drawings / contractor

Reports to:
 2- Client

KLEINFELDER