

## 2035 Central Circle, Suite 110 McKinney, TX 75069

Phone: (972) 542-4362 Fax: (972) 542-4366

# CONCRETE CYLINDER COMPRESSIVE STRENGTH REPORT, ASTM C 39

Report To:

Town of Addison Clay Barnett, PE

16801 Westgrove Drive c/o Public Works Dept

Addison, TX 75001

Report Date: 8/24/2010

Project No.: 99526

Project:

Vitruvian Park and Misc Projs

Task:

5 Phase 1D

### MIX DESIGN DATA

Supplier:

**LMC** 

Mix No.: Cement Type:

5507

Cement Factor (sk/cy):

Time Sampled: 2:06 PM

Max. Size Agg.(in.):

Admixtures:

#### SAMPLE DATA

Date Sampled: 8/17/2010

Date Received:

Time Batched: 1:14 PM

Batch Size (cv): Water Added (gal):

Source of Sample: Pier

Pier A-1

Contractor: WW Drilling Truck/Ticket: 7021/3280877

P. Kidd Sampled By: Submitted By: P. Kidd

Curing Method: Cure Room

Field Cure Temp (°F) Hi:

Lo:

Field Cure Time:

		Specified	
	Measured	Min	Max
Slump (in)	5.25		
Slump w/plasticizer (in)			
Ambient Air Temperature (°F)	101		
Mix Temperature (°F)	95		
Air Content (%)	4.0		
Unit Weight (pcf)			
Time in Truck (mins.)	52		

#### LABORATORY DATA

Capping Method: Unbonded

Sample Number	Date Tested	Age (days)	Dimension Diam.	ons (in) Height	Area (in²)	Fracture Type	Ultimate Load (lbs)	Compressive Strength (psi)
MCK2000060A	8/24/2010	7	4.00	8.00	12.57	Type 5-Side Fracture	38,820	3,090
MCK2000060B	9/14/2010	28						
MCK2000060C	9/14/2010	28						
MCK2000060D	9/14/2010	28						
MCK2000060E		Hold						
Average 7 Day Strength (psi):								

Remarks:

Reviewed on 8/24/2010 by:

Campbell, Bill, Jr., P.E.

Project Manager

Required Strength (psi) @ 28 days:

3.600

Associated Test Methods: ASTM C 31, C 138, C 143, C 172, C 173, C 231, C 617, C 1064, C 1231

Unless prior arrangements have been made all HOLD specimens will be discarded if required strength is attained. Limitations: Pursuant to applicable building codes, the results presented in this report are for the exclusive use of the client and the registered design professional in responsible charge. The results apply only to the samples tested. If changes to the specifications were made and not communicated to Kleinfelder, Kleinfelder assumes no responsibility for pass/fail statements (meets/did not meet), if provided. This report may not be reproduced, except in full, without written approval of Kleinfelder.