


Basin	Area (Ac.)	I_{100}	C	Developed Q_{100} CFS	Detained Q_{100} CFS	Max. W.S. Elev.	Restriction Outlet Size
A1	0.2	8.9	.8	1.4	0.5	663.5	4" Dia.
A2	0.3	8.9	.8	2.1	1.2	663.7	6" Dia.
B1	0.7	8.9	.8	5.0	1.5	660.4	6" Dia.
B2	0.7	8.9	.8	3.7	2.9	657.9	2-6" Dia.
B3	0.5	8.9	.5	2.2	1.3	656.8	6" Dia.
B4	0.4	8.9	.8	2.1	1.2	655.5	6" Dia.
C1	1.2	8.9	.8	8.5	See "E1"	N/A	N/A
C2	0.4	8.9	.8	2.8	See "E1"	N/A	N/A
C3	0.1	8.9	.8	0.7	See "E1"	N/A	N/A
C4	0.2	8.9	.8	1.4	See "E1"	N/A	N/A
C5	0.1	8.9	.8	0.7	See "E1"	N/A	N/A
C6	0.1	8.9	.8	0.7	See "E1"	N/A	N/A
D1	0.7	8.9	.8	3.7	1.4	654.9	6" Dia.
E1	3.8	8.9	.8	27.1 ¹⁰	12.7	654.4	15" Dia.
F1	0.6	8.9	.5	2.7	1.3	653.8	6" Dia.
G1	1.2	8.9	.6	6.4	0.6	652.2	4" Dia.
H1	1.2	8.9	.8	8.5	8.5	N/A	N/A
I1	0.5	8.9	.7	3.1	0.5	651.8	4" Dia.
I2	0.3	8.9	.8	2.1	0.5	650.9	4" Dia.
I3	0.7	8.9	.8	5.0	5.0	N/A	N/A
J1	0.4	8.9	.8	2.8	0.5	651.7	4" Dia.
J2	0.3	8.9	.8	2.1	0.5	651.7	4" Dia.
J3	0.7	8.9	.8	5.0	5.0	N/A	N/A
K1	0.5	8.9	.8	3.6	1.3	650.0	6" Dia.
K2	0.2	8.9	.8	1.4	0.5	656.5	4" Dia.
K3	1.0	8.9	.8	7.1			N/A
K4	0.5	8.9	.8	3.6			N/A
K5	0.6	8.9	.8	4.3	6.0	655.5	2-6" Dia.
K-6	0.6	8.9	.8	4.3			2-6" Dia.
K-7	0.5	8.9	.8	3.6	3.6	N/A	N/A
K-8	0.4	8.9	.8	2.8	2.8	N/A	N/A
K-9	1.7	8.9	.8	12.1	12.1	N/A	N/A
K-10	0.5	8.9	.8	3.6	3.6	N/A	N/A
L-1	0.8	8.9	.8	5.7	5.7	N/A	N/A
M-1	0.4	8.9	.8	2.8	0.7	650.9	4" Dia.
N-1	0.3	8.9	.8	2.1	1.3	649.9	6" Dia.
O-1	2.1	8.9	.8	15.0 ¹⁰	See "P1"	N/A	N/A
P-1	0.3	8.9	.8	2.1	7.8	639.7	6" Dia.

NOTES:
 1. Outlet Restrictions may be accomplished using pipes of the diameter shown or larger pipes which have been restricted by an orifice plate with an opening of the equivalent area at the inlet structure.



* "Special Drainage Easement"
 A "Special Drainage Easement" is established along a portion of the common line between Lot 1 (the "development") and Lot 2 (the "park") to allow for surface runoff from the park and future access to the inlet and pipe system in the development should underground drainage be required in portions of the park. This easement is granted to the Town of Addison for these purposes only and expressly precludes the use of the easement for any other drainage system or utility by anyone other than the owner or his assigns. This easement is also granted subject to the stipulation that repair of any damage to the development property as a result of the installation or maintenance of the Town's systems therein shall be borne by the Town of Addison.

DATE	DESCRIPTION	REF. NO.
12/28/94	CITY SUBMITTAL	
	REVISIONS & ISSUE DATES	

BENCH MARK:
 Top Disk South End Of Curb Inlet On The West Side Of Addison Road 735' +/- North Of Sojourn Drive.
 ELEVATION = 640.12
 * "r" Cut North End Of Recessed Inlet On The West Side Of Westgrove 665' +/- North Of Sojourn Drive.
 ELEVATION = 661.37

DRAINAGE AREA MAP
THE DOMINION
 25.408 ACRES IN 2 LOTS

SITUATED IN THE
 ELI SHEPHERD SURVEY, ABSTRACT No. 1361
 AND LEVI NOBLE SURVEY, ABSTRACT No. 1098
 TOWN OF ADDISON
 DALLAS COUNTY, TEXAS

HUITT - ZOLLARS
 3131 MCKINNEY AVENUE/SUITE 600
 DALLAS, TEXAS/214-871-3311
 HOUSTON, TEXAS 77027
 01-1751-03

CAMDEN PROPERTY TRUST
 3200 SOUTHWEST FREEWAY
 1500 PHOENIX TOWER
 HOUSTON, TEXAS 77027

*14.8 from C1-C6
 *Add to P1
 *1 Sq. Ft. opening grate inlet (25% clogging factor)