



*Del. at this
line to be installed
at Parking Ramp
WSP*

*NOTE: INSTALL DEEP CUT CONNECTION
ON SANITARY SEWER AT LOCATION
SHOWN IN PROFILE*

- NOTES:
1. FIRE HYDRANTS SHALL BE MUELLER CENTURION.
 2. GATE VALVES SHALL BE MUELLER.
 3. WATER LINES SHALL HAVE 48" COVER, MINIMUM, AND CLASS C EMBEDMENT (SAND WRAPPED).

ADDISON, TEXAS	
ADDISON MUNICIPAL AIRPORT WATER & SEWER PLAN	
Riewe & Wischmeyer, Inc. CONSULTING ENGINEERS DALLAS, TEXAS	DESIGNED: R & W APPROVED: R & W DATE: MAY 80
JOB NO. 7930	SHEET NO. 2 of 3 SCALE: 1"=100'